CORRECTION



Correction: The effect of building orientation on energy efficiency

Shahryar Habibi^{1,2}

Published online: 8 March 2024 © Springer-Verlag GmbH Germany, part of Springer Nature 2024

Correction to:

Clean Technologies and Environmental Policy https://doi.org/10.1007/s10098-023-02695-w

In the original publication of the article, an additional piece of information "*R*-Value (m^2 K/W): 11.9" was mistakenly included with the entry "Wall" under the heading "Building elements" in Table 1. It should be removed from the table.

The updated version of Table 1 with the correct information is provided in this correction.

The original article has been corrected.

Table 1 Building components and their value

Building elements	R-value (m ² K/W)	U-value (W/m ² K)
Roof	6.84	0.14
Wall	2.142	0.4668
Glazing	0.3096	3.23
Glazing Solar Heat Gain Coefficient (SHGC)=0.64		
Heating set point ($^{\circ}C$) = 21.11		
Heating set back (°C): 15		
Cooling set point (°C): 23.33		
Cooling set back (°C): 28.88		

Publisher's Note Springer Nature remains neutral with regard to jurisdictional claims in published maps and institutional affiliations.

The original article can be found online at https://doi.org/10.1007/s10098-023-02695-w.

- Shahryar Habibi hbbshr@unife.it; sh.habibi@art.ac.ir
- ¹ University of Ferrara, Ferrara, Italy
- ² Tehran University of Art, Tehran, Iran