Correction to: Energy Benchmarking as a Tool for Energy-Efficient Wastewater Treatment: Reviewing International Applications

Ilda Clos¹ · Jörg Krampe^{1,2} · Juan P. Alvarez-Gaitan³ · Christopher P. Saint¹ · Michael D. Short⁴

Published online: 14 October 2020

© Springer Nature Singapore Pte Ltd. 2020

Correction to: Water Conservation Science and Engineering (2020) 5:115–136

<https://doi.org/10.1007/s41101-020-00086-6>

The original article unfortunately contains cut-off Tables 6&7.
The corrected Tables 6 & 7 should be.

The online version of the original article can be found at <https://doi.org/10.1007/s41101-020-00086-6>

✉ Michael D. Short
Michael.Short@unisa.edu.au

¹ Natural and Built Environments Research Centre, School of Natural and Built Environments, University of South Australia, Mawson Lakes, South Australia 5095, Australia

² Institute for Water Quality and Resource Management, TU Wien, Karlsplatz 13/226, 1040 Vienna, Austria

³ UNSW Water Research Centre, School of Civil & Environmental Engineering, The University of New South Wales, Sydney, New South Wales 2052, Australia

⁴ Future Industries Institute, University of South Australia, Mawson Lakes, South Australia 5095, Australia

Table 6 Guide values in kWh/PE_{BOD60}*y for specific energy consumption in relation to SC and biological treatment of Baumann et al. [31] (data adapted from Baumann et al. [31])

	<1,000 PE [SC 1]	1,000–5,000 PE [SC 2]	5,001–10,000 PE [SC 3]	10,001–100,000 PE [SC 4]	>100,000 [SC 5]
Aerated lagoons	45	40	35	30	-
Rotating biological contactors	35	25	-	-	-
Trickling filter	50	25	25	25	25
Extended aeration	70	45	37	32	-
Activated sludge (AS) ^a	60	45	37	32	30
AS and trickling filters	-	-	-	38	26
<i>Plants targeting nitrification</i>					
☐ <i>Plants targeting nitrogen removal</i>					
^a <i>Plants with separate sludge stabilisation</i>					

Table 7 Target Values in kWh/PE_{BOD60}*y for specific energy consumption in relation to SC and biological treatment of Baumann et al. [31] (data adapted from Baumann et al. [31])

	<1,000 PE [SC 1]	1,000–5,000 PE [SC 2]	5,001–10,000 PE [SC 3]	10,001–100,000 PE [SC 4]	>100,000 PE [SC 5]
Un-aerated lagoons	2	-	-	-	-
Constructed wetland	3	-	-	-	-
Aerated lagoons	32	30	24	22	-
Rotating biological contactors	25	18	15	-	-
Trickling filter	35	15	15	18	18
Extended aeration	35	26	22	20	-
Activated sludge (AS) ^a	29	26	23	20	20
AS and trickling filters	-	-	-	26	18
<i>Plants targeting nitrification</i>					
☐ <i>Plants targeting nitrogen removal</i>					
^a <i>Plants with separate sludge stabilisation</i>					