Design of voltage and current controller parameters using small signal model-based pole-zero cancellation method for improved transient response in microgrids

Y. V. Pavan Kumar¹ · Ravikumar Bhimasingu²

Received: 12 May 2020 / Accepted: 8 September 2021

Published online: 09 October 2021

© The Author(s) 2021

Abstract

Microgrids are supposed to provide stable power for seamless utility-grid interaction under all conditions as stated by IEEE-1547 standard. But, the use of power electronic inverter makes the microgrid sensitive to transients than synchronous generator-based plants. This degrades the voltage/frequency responses during transients, which can lead to transient stability problem if not controlled properly. Hence, the design of effective closed-loop voltage and current (V/I) controllers is highly desired to control the inverter output against the disturbances. The V/I controllers are based on PI (proportional-cum-integral) formulas. Thus, the effectiveness of V/I controllers relies on how accurate that their gain parameters are tuned. Many PI-tuning methods have been developed in the literature, but, it is yet difficult to identify a suitable method for an application. Also, only a few researchers have focused on the microgrids due to the complexity involved in its controller design by the presence of V/I cascaded dual-loop. Hence, to address this problem, this paper proposes a novel way of designing V/I controller parameters by using pole-zero cancellation method. This method is implemented by deriving the microgrid's small-signal model. This improves the transient response through reduced system order and/or alleviated sluggish/marginal-stable/unstable poles by adding zeros at same places where those poles are laid, to in effect cancel them. The efficacy of the proposed method over existing methods is assessed by plotting frequency and voltage responses under different test conditions. From the simulation results, it is witnessed that the proposed method relatively improved the transient characteristics of microgrids.

Article Highlights

- Analyzes the applicability of conventional PI tuning methods for microgrid controllers' design.
- Proposes a novel small signal model based pole-zero cancellation method for the design of microgrid controllers.
- Enhances the gain margin, which improves the stabilization capacity of the system when subjected to disturbances.
- Improves the transient behavior of frequency and voltage responses, which ensure the safety of sensitive loads.

Keywords Microgrids · Voltage controller · Current controller · PI tuning · Small-signal model · Transient response

✉ Y. V. Pavan Kumar, pavankumar.yv@vitap.ac.in | ¹School of Electronics Engineering, VIT-AP University, Amaravati 522237, Andhra Pradesh, India. ²Department of Electrical Engineering, Indian Institute of Technology Hyderabad (IITH), Hyderabad 502285, Telangana, India.

Nomenclature

Acronyms

CLTF	Closed-loop transfer function
EPI	Error Performance Index
MG	Microgrid
MPZC	Small signal model based pole-zero cancellation
OLTR	Open-loop transient response
OLTF	Open-loop transfer function
PEVSI	Power electronic voltage source inverter
PIC	Proportional-integral controller
PWM	Pulse width modulation
PZC	Pole-zero cancellation
RESM	Renewable energy sourced microgrid
THD	Total harmonic distortion
UG	Utility-grid
V/I	Voltage and current

Variables and Parameters

1 Three-Phase Parameters

R_f^{abc}, L_f^{abc}	Series resistance (Ω), Series inductance (mH) of filter
C_f^{abc}, G_f^{abc}	Shunt capacitance (μF), conductance (S) of filter
R_g^{abc}, L_g^{abc}	Line resistance (Ω), Line inductance (mH) of grid
V_o^{abc}, I_o^{abc}	Load bus measurements—voltage (V), current (A)
V_{pwm}^{ref}	Reference input (V) given to PWM generator
V_s^{abc}	Inverter output voltage (V)
V_i^{abc}	Series branch voltage (V) of the filter
I_i^{abc}	Current (A) drawn from the Inverter
V_g^{abc}	Utility-grid voltage (V)
I_c^{abc}	Current (A) flowing in shunt branch of Filter

dq Parameters

V_o^{dq}, V_{qo}^{dq}	$V_{do}, V_{qo} = dq$ Equivalents of V_o^{abc} (V)
I_o^{dq}, I_{qo}^{dq}	$I_{qo}, I_{do} = qd$ Equivalents of I_o^{abc} (A)
$V_{do}^{ref}, V_{qo}^{ref}$	Reference inputs given to voltage controller (V)
$I_{di}^{ref}, I_{qi}^{ref}$	Reference current inputs of current controller (A)
e_d, e_q	dq Components of V_{pwm}^{ref} (V)
I_{di}^{dq}, I_{qi}^{dq}	$I_{qi}, I_{di} = qd$ Components of I_i^{abc} (A)
$I_{di}^{ref}, I_{qi}^{ref}$	I_{di}^{ref} or I_{qi}^{ref} = Reference current for I_i control (A)
V_o^{ref}, V_{qo}^{ref}	V_{do}^{ref} or V_{qo}^{ref} = Reference voltage for V_o control (V)

Single-Phase Parameters

R_f, L_f	Single phase representation of R_f^{abc}, L_f^{abc}
C_f, G_f	Single phase representation of C_f^{abc}, G_f^{abc}
R_g, L_g	Single phase equivalent of R_g^{abc}, L_g^{abc}
V_s, V_i, V_o	Single phase equivalent of $V_s^{abc}, V_i^{abc}, V_o^{abc}$
I_i, I_c, I_o	Single phase equivalent of $I_i^{abc}, I_c^{abc}, I_o^{abc}$

Other Parameters

V_{dc}^{mg}, V_{ac}^{mg}	Microgrid's DC, AC bus voltages respectively (V)
ω	Angular frequency (rad/sec)
K_{pV}, K_{iV}	PIC components of voltage controller
K_{pA}, K_{iA}	PIC components of current controller

1 Introduction

The modern power system is facing profound changes by the integration of more and more renewable energy sourced microgrid (RESM) plants to the utility-grid to get rid of issues with conventional fossil fuel-based energy. However, the fruitful operation of RESMs is majorly affected by the intermittent renewable energy availability and dependency on harmonic prone power electronic voltage source inverter (PEVSI). Further, as a general-purpose utility grade plant, the RESM needs to be operated under typical industrial/residential load conditions that have a wider degree of variability. These variabilities mainly include imbalances in the load-bus voltage or utility-grid voltage due to single-phase distribution systems, nonlinear load actions, momentary faults, disturbances, etc. Compared to synchronous generator-based power plants, PEVSI-based RESMs possess negligible inertia and kinetic energy. So, RESMs are considered sensitive, which produce degraded voltage and frequency response during the variabilities mentioned above [1–3]. These degraded responses can further lead to transient stability problem if not controlled appropriately. To address the above-mentioned issues, the state-of-the-art solutions suggest, optimal use of storage devices to handle the irregularity in renewable energy availability [4–6], refined multilevel or modular PEVSI configurations with reduced complications (e.g., fault tolerant operations during switch failures, use of less number of circuit components, etc.) to handle harmonic distortion issues [7–9], and the development of different voltage and current (V/I) control methods [10–12] and droop control methods [13–15] to handle power quality and power sharing issues, respectively. All these

solutions help to improve the RESM's steady-state stability, but, the concerns of oscillatory responses during small-signal disturbances are yet predominant. These transient response issues rely on the timely response and fidelity of the PEVSI's controller, i.e., the V/I controllers.

In each closed-loop control cycle, the V/I controllers produce the control (or reference/modulation) signal to the PWM generator as given in Fig. 1 by controlling the load variations and disturbances occurred at the load-bus. Based on this control signal, the PWM generator produces the necessary firing pulses to regulate the PEVSI output. The V/I controllers are the proportional-integral controller (PIC)-based algorithms. Therefore, the desired operation of V/I controllers to address the transient response issues depend on the accurate design of its PIC gain parameters.

To design gain parameters of PICs used in different applications, there are several tuning methods have been continuously evolving as discussed in [16–24]. Apart from these conventional methods, pole-zero cancellation (PZC) method is being used to design PICs in different applications such as, design of pulse pile-up tracking system used in amplifiers to generate lower noises [25], design of harmonic controller for a STATCOM [26], in multistage amplifiers to decrease the size of compensation capacitor, output power transistor, and to increase the power-bandwidth efficiency [27], for reducing the forced vibration in an end milling process application [28], for high speed sample and hold circuit design used in pipeline analog–digital converters [29], design of CdTe diode-based radiation detectors [30], design of gain scheduling control method for DC/DC converter [31], design of low noise power amplifier used in UWB systems [32], for increasing the phase and gain margin in feedback systems [33], design of current

controller for electric machines [34], design of 3-phase synchronous reference frame PLLs [35], design of levitated object position controller for magnetic levitation systems [36], in CMOS transconductance operational amplifiers with the help of settling time computations [37], to expand the bandwidth of dual-mass MEMS gyroscopes [38], in first-order and time-delay systems for rate limiting of actuators [39], etc.

The concept of PZC method is to compensate the unstable poles (open-loop right-half-plane poles) or sluggish/marginal stable poles (poles at or nearby origin) by adding zeros at the same locations where those undesired poles are laid, to in effect compensates the effect of those poles. Despite using the PZC method effectively in controller design for many applications, while, to the best of authors' knowledge based on the above-reported literature, it has never been used to design the V/I controllers of RESMs. Hence, the applicability of PZC method for the design of dual-loop V/I controllers for RESMs is worthy of serious consideration. With this objective, this paper proposes the "Small Signal Model Based Pole-Zero Cancellation (MPZC) method" to design the PIC parameters of V/I controllers used in RESMs. The contributions of this paper are outlined as follows.

- Analyzing the applicability of conventional PIC tuning methods discussed in [16–24] for the design of RESM's controller. A quantitative analysis is presented in Sect. 5.1. This analysis further helps to identify the best conventional method to compare with the proposed method to persuade the importance of the proposed method.
- Design of the proposed MPZC methodology for the design of V/I controller gains to achieve the improved

Fig. 1 Representation of the renewable energy sourced microgrid (RESM) plant

transient response in RESMs over the conventional methods.

- Conducting adequate simulation analysis with different test conditions to judge the usefulness of the proposed method compared to the conventional methods.

The other sections of the paper are arranged as follows. Section 2 describes the V/I controller operation in RESMs. Section 3 describes the development of proposed small signal model of the RESM. Section 4 describes the development of conventional and proposed methods for designing the PIC parameters used in V/I controllers. Section 5 presents the comparative results, which also includes the analysis on the applicability of conventional tuning methods for the design of RESM's V/I controller. To conclude, Sect. 6 provides the cumulative remarks and achievements of this paper.

2 Description of the V/I controller operation

The RESM schematic shown in Fig. 1 is an integrated entity of renewable sources with associated converters, storage units, PEVSI, V/I controllers, load, and utility-grid connection. The V/I controller works in a closed-loop between the AC (or load) bus and the PEVSI. This is formed with the cascaded connection of voltage and current controllers given in Fig. 2a and Fig. 2b [3]. The corresponding operational relations of V/I controller are given as (1)–(6), which produces the three-phase reference signal to PWM generator as referred in (7), using the inverse park transformation formula. Based on this reference (or modulation) signal, the PWM generator produces the switching signals to control the PEVSI's switches, which subsequently controls its output.

$$I_{di}^{ref} = I_{do} + V_{do}G_f + (K_{PV} + K_{IV}/s)(V_{do}^{ref} - V_{do}) - V_{qo}\omega C_f \quad (1)$$

$$I_{qi}^{ref} = I_{qo} + V_{qo}G_f + (K_{PV} + K_{IV}/s)(V_{qo}^{ref} - V_{qo}) + V_{do}\omega C_f \quad (2)$$

$$e_d = V_{do} + I_{di}R_f + (K_{PA} + K_{IA}/s)(I_{di}^{ref} - I_{di}) - I_{qi}\omega L_f \quad (3)$$

$$e_q = V_{qo} + I_{qi}R_f + (K_{PA} + K_{IA}/s)(I_{qi}^{ref} - I_{qi}) + I_{di}\omega L_f \quad (4)$$

$$\therefore e_d = (V_{do} + I_{di}R_f - I_{qi}\omega L_f) + \left(\frac{K_{IA} + sK_{PA}}{s}\right) \times \left(I_{do} - I_{di} + V_{do}G_f + \frac{(K_{IV} + sK_{PV})(V_{do}^{ref} - V_{do})}{s} - V_{qo}\omega C_f\right) \quad (5)$$

$$\therefore e_q = (V_{qo} + I_{qi}R_f + I_{di}\omega L_f) + \left(\frac{K_{IA} + sK_{PA}}{s}\right) \times \left(I_{qo} - I_{qi} + V_{qo}G_f + \frac{(K_{IV} + sK_{PV})(V_{qo}^{ref} - V_{qo})}{s} + V_{do}\omega C_f\right) \quad (6)$$

$$V_{pwm}^{ref} = \begin{bmatrix} V_a^{ref} \\ V_b^{ref} \\ V_c^{ref} \end{bmatrix} = \begin{bmatrix} \sin(\omega t) & \cos(\omega t) & 1 \\ \sin(-120^\circ + \omega t) & \cos(-120^\circ + \omega t) & 1 \\ \sin(120^\circ + \omega t) & \cos(120^\circ + \omega t) & 1 \end{bmatrix} \begin{bmatrix} e_d \\ e_q \\ e_o \end{bmatrix} \quad (7)$$

Further, from (5) and (6), it can be seen that the effectiveness of the reference PWM signal, thereby the V/I control system majorly depends upon the values of PIC gains (K_{PA} , K_{IA} , K_{PV} , K_{IV}). Hence, it is intoned that the operation of the V/I controller depends on the proper tuning of its PIC gains.

Fig. 3 Model of the phase-locked loop

Fig. 2 Models of voltage and current (V/I) controllers used for RESM control

Table 1 Parameters used for the PLL design

Parameter	Description	Value
τ_{PLL}	Time constant of PLL	1 ms
K_p^{PLL}	Proportional gain	1.5476
K_i^{PLL}	Integral gain	14.9814

Fig. 4 Simplified circuit representation of the RESM plant**Table 2** Assumptions for the design of proposed method

S. No	Assumptions
1	As the focus of the work is to improve transient response that is affected due to load side dynamics, the source side dynamics are not considered in the design. So, the renewable energy sources and the PEVSI is combined and considered as a simplified single AC source (V_s^{abc}) as shown in Fig. 4
2	In the design of the low-pass filter, the primary focus is kept on the filter inductance (L_f) and capacitance (C_f) parameters, which has a critical impact on the RESM operation. As the effect of filter resistance (R_f) and conductance (G_f) is negligible, these values are chosen arbitrary minimum to simplify the system transfer function

For the operation of V/I controller, the phase-locked loop (PLL) is used for the calculation of a phase angle for d - q transformation and the frequency of input voltage waveform. The block diagram of PLL is given in Fig. 3. Here, abc - dq transformation is used to get V_{qo} , V_{do} ; the q and d components of V_o^{abc} (voltage measured at the load bus). The modeling specifications given in Table 1 are used to design the PLL.

Fig. 5 Uncontrolled RESM plant model

3 Development of the proposed small signal model of the microgrid

The RESM schematic shown in Fig. 1 is represented as the simplified equivalent circuit shown Fig. 4 to develop its small signal model with respect to the assumptions given in Table 2. Here, UG and MG indicate the utility-grid and microgrid terminals, respectively. The objective of this model is to implement the proposed MPZC-based design method for the V/I controller that controls the load voltage/outer-loop voltage (V_o^{abc}), and PEVSI's current/inner-loop current (I_i^{abc}), whose single-phase parameters are represented as $V_o(s)$ and $I_i(s)$, respectively, and are related through (8)–(11). From (9) and (11), the uncontrolled microgrid plant model is obtained, as shown in Fig. 5, where the output and input are related as (12).

$$V_o(s) = V_s(s) - V_i(s) \quad (8)$$

$$\therefore I_i(s) = \frac{V_i(s)}{R_f + sL_f} = \frac{V_s(s) - V_o(s)}{R_f + sL_f} \quad (9)$$

$$I_i(s) = I_o(s) + I_c(s) \Rightarrow I_c(s) = I_i(s) - I_o(s) \quad (10)$$

$$\therefore V_o(s) = \frac{I_c(s)}{G_f + C_f s} = \frac{I_i(s) - I_o(s)}{G_f + C_f s} \quad (11)$$

$$\Rightarrow V_o(s) = \frac{V_s(s) - (R_f + L_f s)I_o(s)}{1 + (G_f + C_f s)(R_f + L_f s)} \quad (12)$$

3.1 Transfer function of the inner current controller

The goal of the current controller is to regulate the current drawn from PEVSI ($I_i(s)$). So, to derive the transfer function of the current controlled inner loop, the influence of the voltage controlled outer loop is ignored. The current controller model is developed as given in Fig. 6, where,

Fig. 6 Model of the current controller of the RESM plant

Fig. 6a gives the conceptual model to realize the current controller, Fig. 6b shows its total model, and Fig. 6c shows its simplified model. From Fig. 6c, the CLTF and thereby, the controlled current is obtained as given in (13) and (14), respectively.

$$\frac{I_i(s)}{I_i^{ref}} = \frac{\left(\frac{K_{IA} + K_{PA}s}{s(R_f + L_f s)} \right)}{1 + \left(\frac{K_{IA} + K_{PA}s}{s(R_f + L_f s)} \right)} = \frac{K_{IA} + K_{PA}s}{s(R_f + L_f s) + K_{PA}s + K_{IA}} \quad (13)$$

$$\therefore I_i(s)|_{innerloop} = \frac{K_{PA}s + K_{IA}}{L_f s^2 + (R_f + K_{PA})s + K_{IA}} I_i^{ref} \quad (14)$$

$$\frac{V_o(s)}{V_o^{ref}} = \frac{\left(\frac{K_{PV}s + K_{IV}}{s(G_f + C_f s)} \right)}{1 + \left(\frac{K_{PV}s + K_{IV}}{s(G_f + C_f s)} \right)} = \frac{K_{PV}s + K_{IV}}{s(G_f + C_f s) + K_{PV}s + K_{IV}} \quad (15)$$

$$\therefore V_o(s)|_{outerloop} = \frac{K_{PV}s + K_{IV}}{C_f s^2 + (G_f + K_{PV})s + K_{IV}} V_o^{ref} \quad (16)$$

3.2 Transfer function of the outer voltage controller

The goal of the voltage controller is to regulate the voltage across the load ($V_o(s)$). So, to derive the transfer function of the voltage controlled outer loop, the effect of the current controlled inner loop is ignored. The voltage controller model is developed as given in Fig. 7, where, Fig. 7a gives the conceptual model to realize the voltage controller, Fig. 7b shows its total model, and Fig. 7c shows its simplified model. From Fig. 7c, the CLTF and thereby,

Fig. 7 Model of the voltage controller of the RESM plant

the controlled voltage is obtained as given in (15) and (16), respectively.

3.3 Transfer function of the overall microgrid system

The V/I controllers' transfer function models are inserted into the uncontrolled plant model to develop the controlled plant model so that the controlled RESM plant model can be represented with a view of dual-control loops as denoted in Fig. 8. The output and input of this system are related through the transfer function given by (17). Equations (18) and (19) represent the OLTF and CLTF of the RESM plant, respectively. Hence, the small signal model of the microgrid plant is derived, as represented in Fig. 9, which is obtained based on (17)–(19). The integration of the three sub-models, viz., uncontrolled plant model given in Fig. 5, the current controller model given by Fig. 6, and the voltage controller model given in Fig. 7 derive this overall model.

$$\frac{V_o(s)}{V_o^{ref}} = \text{Closedloopof} (F_1(s) \times F_2(s) \times F_3(s)) \quad (17)$$

where;

Fig. 8 Simplified dual-loop V/I controlled RESM model

$$\begin{cases} F_1(s) = \frac{K_{IV} + sK_{PV}}{s} \\ F_2(s) = Cl.loop \left(\frac{K_{IA} + sK_{PA}}{s(L_f + R_f)} \right) = \frac{K_{IA} + sK_{PA}}{s^2 L_f + (R_f + K_{PA})s + K_{IA}} \\ F_3(s) = \frac{1}{G_f + C_f s} \end{cases}$$

$$\begin{cases} \therefore F_1(s) \times F_2(s) \times F_3(s) = \\ \frac{K_{PA}K_{PV}s^2 + s(K_{PV}K_{IA} + K_{IV}K_{PA}) + K_{IA}K_{IV}}{(L_f C_f s^4 + (C_f K_{PA} + G_f L_f + R_f C_f)s^3 + (G_f R_f + K_{PA}G_f + K_{PV}K_{PA} + C_f K_{IA})s^2 + (K_{PV}K_{IA} + G_f K_{IA} + K_{IV}K_{PA})s + K_{IA}K_{IV}} \end{cases} \quad (18)$$

$$\therefore \frac{V_o(s)}{V_o^{ref}} = \frac{(K_{PA}K_{PV})s^2 + (K_{IV}K_{PA} + K_{PV}K_{IA})s + K_{IA}K_{IV}}{(L_f C_f s^4 + (R_f C_f + G_f L_f + K_{PA}C_f)s^3 + (G_f R_f + K_{PA}G_f + K_{PV}K_{PA} + C_f K_{IA})s^2 + (K_{PV}K_{IA} + G_f K_{IA} + K_{IV}K_{PA})s + K_{IA}K_{IV}} \quad (19)$$

4 Tuning of the V/I controller parameters

By the observation of small signal model shown in Fig. 9, the system control depends upon two parameters, viz., filter parameters (R_f , L_f , C_f , G_f) and PIC parameters of V/I controller (K_{PV} , K_{IV} , K_{PA} , K_{IA}). Hence, the proper design of these parameters improves the RESM's response. With this intent, this section focuses on the tuning methods of controller parameters. The filter specifications are designed based on the relations expressed in (20) and (21) [40]. The computed values and the other considerations are given in Table 3.

$$C_f = \frac{2P_r}{F_s V_{dc}(\Delta V_{ac})} \quad (20)$$

$$L_f = \frac{1}{(2\pi F_r)^2 C_f} \quad (21)$$

where ΔV_{ac} and F_r are chosen as per the power quality requisites given by IEEE-1547, IEEE-519 standards.

Fig. 9 Small signal model of the microgrid plant involving V/I controllers

Table 3 Parameters used for the controller design/testing

Parameter	Description	Specification
$P_r + jQ_r$	Rated power of RESM	25 kW + j25 kVAR
V_{dc}	PEVSI's input DC voltage	540 V
ΔV_{ac}	Maximum deviation allowed in the PEVSI output voltage	± 62 V
F_s	Switching frequency used for producing PEVSI's PWM signals	15 kHz
F_r	Minimum ripple frequency component exist in the grid current	600 Hz
C_f	Capacitance used for filter design	50 μ F
L_f	Inductance used for filter design	1.35 mH
R_f	Resistance used for filter design	0.1 Ω
G_f	Conductance used for filter design	0 Ω

Table 4 Steps involved in OLTR and EPI tuning methods

Step-1 Remove all the feedback/feedforward loops and the controller from the plant, so that no control action involved in the plant response

Step-2 Excite the plant with a step input and observe its open-loop response as referred in Fig. 10

Step-3 By using the inflection point as the basis, draw the tangent to this open-loop curve. From this, measure the value of dead time (T_d), time constant (τ_c), stationary gain (K_s), and tangent slope (M)

Step-4 Compute the PI specifications using Tables 5 and 6 [41, 42]. The corresponding computed values are given in Table 7

4.1 Conventional methods for tuning V/I controller gain

Among many conventional tuning methods as discussed in Sect. 1, more suitable methods such as OLTR and EPI methods (which were widely used in the literature for similar applications and can exhibit tolerable transient stability responses) are chosen to validate the proposed method against them. These OLTR and EPI methods work on the plant's open-loop response with respect to design procedural steps given in Table 4 [17, 41, 42]. As the RESM's controller involves V/I dual-loops, the tuning steps given in Table 4 has to be repeated for those two loops. The limitations of these conventional OLTR and EPI methods are given as follows.

- Due to the presence of interdependent dual control loops, as mentioned above, the use of these conventional methods for RESM application is quite questionable.
- The measured parameters (T_d , τ_c , K_s , M) from the open-loop response as described in Table 4 need to be more accurate for precise design of PIC gain parameters.
- By considering the limitations described above, Sect. 5.1 gives a quantitative analysis to understand the applicability of these conventional methods to RESMs application.

4.2 Proposed method for tuning V/I controller gains

This section describes the development of the proposed MPZC method for the tuning of V/I controllers' parameters as below.

Fig. 10 Open-loop response curve

Table 5 Formulae to tune PIC by OLTR and EPI methods

Method	Proportional gain (K_p)	Integral time constant (T_i)
ZN-1	$0.9/MT_d$	$3.3T_d$
WJC	$\left(0.73 + \frac{0.53\tau_c}{T_d}\right) \frac{(\tau_c + 0.5T_d)}{K_s(\tau_c + T_d)}$	$\tau_c + 0.5T_d$
CHR	$0.35/MT_d$	$1.2T_d$
CC	$\frac{0.9}{MT_d} \left(1 + \frac{0.92\tau_c}{1 - \tau_c}\right)$	$\frac{3.3 - 3\tau_c}{1 + 1.2\tau_c} T_d$
EPI	$\frac{a_1}{K_s} \left(\frac{T_d}{\tau_c}\right)^{b_1}$	$\tau_c \left(a_2 + b_2 \left(\frac{T_d}{\tau_c}\right)\right)^{-1}$

4.2.1 Procedure for tuning current controller parameters

From the simplified current controller model realized in Fig. 6c, the OLTF for controlling the inner-loop current or current drawn from the PEVSI ($I_i(s)$) is obtained as (22). From this, the open-loop poles of the current controller model are obtained as (0) and $(-R_f/L_f)$, where, one pole ($s = 0$) represents marginal stability, and another pole ($s = -R_f/L_f$) represents near marginal stability due to very lower (R_f) value for RESMs as explained in Table 2. Hence, these two poles lead to sluggish plant's response and thereby, exhibits poor transient response during disturbances. The issue mentioned above can be alleviated by the proposed MPZC method. To achieve this, it is proposed to consider (23), so that the near marginal stable pole gets cancelled with the zero. The near marginal stable pole is a dominant pole, which is responsible for the system dynamics. The idea of compensating the effect of this dominant pole highly influences the dynamics of the closed-loop system. The resultant OLTF is obtained as (24), where the second-order system (22) is transformed to a first-order system. This exhibits improved transient responses by damping out the natural oscillatory response of second-order systems. Further, (25) denotes the CLTF of the current controller used to design its gain parameters.

$$\left. \frac{I_i(s)}{I_i^{ref}} \right|_{openloop} = \frac{K_{IA} + sK_{PA}}{s(R_f + sL_f)} = \frac{K_{PA}}{sL_f} \left(\frac{s + (K_{IA}/K_{PA})}{s + (R_f/L_f)} \right) \quad (22)$$

Table 6 Design constants used in EPI tuning methods

Criterion	ISE	ISTSE	ISTE	ITAE
a_1	1.048	0.968	1.042	0.965
a_2	1.195	0.977	0.987	0.796
b_1	-0.897	-0.904	-0.897	-0.85
b_2	-0.368	-0.253	-0.238	-0.1465

Table 7 V/I Controller gains tuned by OLTR/EPI methods

Method	Current controller			Voltage controller		
	K_{PA}	T_{IA}	K_{IA}	K_{PV}	T_{IV}	K_{IV}
<i>OLTR Methods</i> ($T_d(s)=0.01$; $\tau_c(s)=0.0164$; $K_s=10$; $M=609.76$)						
ZN-1	0.015	0.033	4.473	$9e^{-4}$	0.33	$27.3e^{-4}$
WJC	0.129	0.021	6.065	$3.66e^{-4}$	0.05	$73.2e^{-4}$
CHR	0.057	0.012	4.783	$3.5e^{-4}$	0.12	$29.2e^{-4}$
CC	0.149	0.032	4.702	$9e^{-4}$	0.33	$27.3e^{-4}$
<i>EPI Methods</i> ($T_d(s)=0.1$; $\tau_c(s)=1.5 \times 10^{-4}$; $K_s=1 \times 10^3$; $M=1 \times 10^4$)						
ISE	0.163	0.017	9.665	$3.07e^{-6}$	$-6.14e^{-7}$	-5
ISTE	0.162	0.019	8.331	$3.05e^{-6}$	$-9.51e^{-7}$	-3.207
ISTSE	0.151	0.019	7.595	$2.71e^{-6}$	$-8.95e^{-7}$	-3.028
ITAE	0.147	0.023	6.329	$3.84e^{-6}$	$-1.55e^{-6}$	-2.476

$$\text{Assume } \frac{K_{IA}}{K_{PA}} = \frac{R_f}{L_f} \quad (23)$$

$$\Rightarrow \left. \frac{I_i(s)}{I_i^{ref}} \right|_{openloop}^{MPZC} = \frac{K_{PA}}{sL_f} \quad (24)$$

$$\left\{ \begin{array}{l} \therefore \left. \frac{I_i(s)}{I_i^{ref}} \right|_{closedloop}^{MPZC} = \frac{(K_{PA}/sL_f)}{1 + (K_{PA}/sL_f)} = \frac{K_{PA}}{K_{PA} + sL_f} \\ = \frac{1}{1 + s(L_f/K_{PA})} = \frac{1}{1 + s\tau_1} \end{array} \right. \quad (25)$$

where ($\tau_1 = L_f/K_{PA}$) represents the current controller's time constant (or V/I controller's inner-loop time constant). Hence, from (23) and (25), current controller's parameters (K_{PA} , K_{IA}) are computed by selecting proper filter parameters (R_f , L_f) as given in Table 3 and suitable lower time constant (τ_1). The resultant calculated values are given in Table 8.

4.2.2 Procedure for tuning voltage controller parameters

From the simplified voltage controller model realized in Fig. 7c, the OLTF for controlling the outer-loop voltage or load voltage ($V_o(s)$) is obtained as (26). This includes $G_f=0$ as given in Table 3, as it is already mentioned that the effect

of G_f is negligible for RESMs application. Equation (26) represents a second-order system transfer function with two poles at the origin. This leads to severe oscillatory responses due to having marginal stability characteristics, which may become unstable for specific conditions and stable for certain other conditions. The issue mentioned above can be alleviated by the proposed MPZC method. To realize this, it is proposed to consider (27), which cancels one pole at the origin. The resultant OLTF is derived as (28), where the second-order system (26) is transformed to first-order system. This exhibits improved transient response by damping out the severe oscillatory responses, as mentioned above. Further, (29) gives the CLTF of the voltage controller that is used to design its gain parameters.

$$\left. \frac{V_o(s)}{V_o^{ref}} \right|_{openloop} = \left(K_{PV} + \frac{K_{IV}}{s} \right) \left(\frac{\overbrace{1}^{1/C_f s}}{\underbrace{G_f}_{=0} + C_f s} \right) = \frac{K_{PV}s + K_{IV}}{C_f s^2} \quad (26)$$

Assume the Voltage controller's Integral Gain

$$K_{IV} = 0 \quad (27)$$

$$\Rightarrow \left. \frac{V_o(s)}{V_o^{ref}} \right|_{openloop}^{MPZC} = \frac{K_{PV}}{C_f s} \quad (28)$$

Table 8 Computed parameters of V/I controllers

Parameter	Description	Value
τ_1	Current control—inner loop time constant	15 ms
τ_2	Voltage control—outer loop time constant	90 ms
K_{PA}	Proportional controller specification of the current controller	0.12
K_{IA}	Integral controller specification of the current controller	6.7
K_{PV}	Proportional controller specification of the voltage controller	$5.65e^{-4}$
K_{IV}	Integral controller specification of the voltage controller	0

$$\left\{ \begin{aligned} \therefore \frac{V_o(s)}{V_o^{ref}} \Big|_{\text{closedloop}}^{MPZC} &= \frac{(K_{PV}/sC_f)}{1 + (K_{PV}/sC_f)} = \frac{K_{PV}}{sC_f + K_{PV}} \\ &= \frac{1}{1 + s(C_f/K_{PV})} = \frac{1}{1 + s\tau_2} \end{aligned} \right. \quad (29)$$

where $(\tau_2 = C_f/K_{PV})$ represents the voltage controller's time constant (or V/I controller's outer-loop time constant). Hence, from (29), tuning of K_{PV} of the voltage controller is achieved by selecting suitable time constant ($\tau_2 \geq 5\tau_1$) and filter parameter (C_f) given in Table 3. The resultant computed value is given in Table 8.

4.3 Rationale of the proposed MPZC method

The overall system's CLTF given by (19) can be implemented with the parameter values obtained with respect to the conventional and proposed control methods discussed in Sects. 4.1 and 4.2. Hence, by substituting these parameter values given in Tables 3, 7, and 8, the system transfer function can be revised as given in (30) and (31) with respect to the conventional CC method and proposed MPZC method. From there, it can be understood that the use of the proposed MPZC method reduces the system size (order), which leads to the improvement of its transient response.

$$\frac{V_o(s)}{V_o^{ref}} \Big|^{CC} = \frac{1.99s^2 + 68.72s + 190.17}{0.001s^4 + 0.18s^3 + 5.47s^2 + 68.72s + 190.17} \quad (30)$$

$$\frac{V_o(s)}{V_o^{ref}} \Big|^{MPZC} = \frac{s + 56.08}{0.001s^3 + 0.163s^2 + 5.97s + 56.08} \quad (31)$$

5 Comparative results and analysis

As per the objective of the paper, the results are segregated into two parts for the analysis, viz., (i) quantitative analysis on the applicability of conventional methods for RESMs, and (ii) comparative analysis of proposed and conventional methods subjected to various test conditions.

5.1 Analysis on the applicability of conventional tuning methods for microgrids

As discussed in Sect. 4.1, conventional methods, viz., OLTR (ZN-1, WJC, CHR, CC) and EPI (ISE, ISTE, ISTSE, IATE) are tested for their applicability to RESM. The efficacy of these methods is assessed in two test modes, viz., one is when

Fig. 11 Response of the single-control loop system (current controller based RESM) with conventional OLTR and EPI methods

Fig. 12 Response of the dual-control loop system (V/I controller based RESM) with conventional OLTR and EPI methods

using for parameter tuning in the single-loop system, i.e., only the current controller (or inner-loop) based RESM and another is when using for parameter tuning in dual-loop system, i.e., for V/I controller-based RESM. In both the test modes, time-domain and frequency-domain responses are plotted during the normal condition (no disturbance) as shown in Fig. 11 and Fig. 12 to understand the applicability of OLTR and EPI methods to RESMs. Various time-domain index (viz., delay time (T_{dt}), rise time (T_{rt}), settling time (T_{st}), peak-overshoot (P_{ov})) and frequency-domain index (viz., phase margin (PM), gain margin (GM)) are computed to

identify the superior method among these conventional methods. From these results, the following remarks could be noted.

- *For the single-control loop-based system* From Fig. 11, it is observed that all the conventional OLTR and EPI tuning methods worked satisfactorily as per the computed frequency/time-domain performance index.
- *For the dual-control loop-based system* From Fig. 12a, c, it is observed that the OLTR methods worked satisfactorily. But, From Fig. 12b, d, it is clear that the EPI meth-

Table 9 Performance comparison of OLTR and EPI methods

Index	ZN	WJC	CHR	CC	ISE	ISTE	ISTSE	IATE	Superior
<i>For single-control loop based RESM system</i>									
T_{dt} (s)	0.025	0.009	0.019	0.008	0.008	0.009	0.009	0.01	CC, ISE
T_{rt} (s)	0.039	0.043	0.045	0.063	0.025	0.029	0.034	0.043	ISE
T_{st} (s)	0.052	0.067	0.061	0.098	0.038	0.049	0.05	0.07	ISE
P_{ov} (%)	2.3	0	0	0	0	0	0	0	All except ZN
GM (dB)	∞	∞	∞	∞	∞	∞	∞	∞	–
PM (deg)	90.50	97.65	92.70	98.55	99.00	99.45	99.18	98.10	ISTE
<i>For dual-control loop based RESM system</i>									
T_{dt} (s)	0.055	0.07	0.09	0.05	Can't determine (unstable)				CC
T_{rt} (s)	0.06	0.085	0.11	0.09					ZN
T_{st} (s)	0.475	1.07	0.88	0.475					ZN, CC
P_{ov} (%)	18.5	60.5	43	17.5					CC
GM (dB)	∞	∞	∞	∞					–
PM (deg)	90	90	90	90					All

ods which worked well for single-control loop-based system are failed for dual-control loop system and leads to instability.

The corresponding performance index is also undetermined from Fig. 12b, d. Hence, a pole-zero plot is drawn, as shown in Fig. 12e to observe the location of poles. Form this, it is seen that, EPI methods lead to the existence of open-loop pole (or closed-loop zero) located on the very far right-half of s-plane, which represents an unstable system.

As it is advised by IEEE-1547, IEEE-519 standards to use both V/I control loops for robust RESM operation during transients, and based on the observations described above, it is concluded that the EPI methods are not suitable for RESMs application. Further, from Table 9, it is understood that the CC method shows better response in most of the index compared to other methods. Hence, the CC method is considered to assess the usefulness of the proposed MPZC method when subjected to different test conditions.

5.2 Comparative analysis of the proposed method and conventional method

To justify the efficacy of the proposed method, different test cases referred in Table 10 are applied, and the corresponding results of proposed MPZC method and conventional best (CC) method are compared. These test cases are considered in a way to resemble practical smoothly varying reactive load as well as largely varying nonlinear load (e.g., arc furnace, welding machines, etc.). The resultant simulation results are shown through Fig. 13, 14, 15 and 16 and the collective quantitative comparisons with respect to the standard tolerances are provided in Table 11.

Test case- T_1 (of Table 10) is used to examine the stabilization capacity of the RESM system subjected to conventional and proposed methods. For analysis, time-domain and frequency-domain responses are plotted as given in Fig. 13. From Fig. 13a, it is seen that, even with more rise time, the proposed method leads to smooth response with faster settling time compared to the conventional method. Another major benefit is that it exhibits zero overshoot at startup, while it is dominant (18.5%) when using the conventional method. Similarly, from the frequency-domain

Table 10 Test cases implemented for comparative analysis

Case	Condition	Specifications/description
T_1	No disturbance	Normal operating condition
T_2	Momentary huge reactive load ON	Inject a sinusoidal voltage (amplitude = 0.5 pu, frequency = 10 Hz, sampling time = 0.01 s) during (1.2–1.4) s
T_3	Highly nonlinear load ON	Inject a band-limited white noise disturbance (amplitude = ± 1 pu varying, sampling time = 5 ms) during (1.2–1.4) s

Table 11 Quantitative comparison of outcomes achieved with proposed and conventional methods

Performance Comparison Index		Result identifier	Conventional CC method	Proposed MPZC method	Standard tolerance
Stability Performance	Delay time (T_{dt}) (s)	Test: T ₁ , Fig. 13	0.05	0.06	
	Rise time (T_{rt}) (s)		0.075	0.14	
	Settling time (T_{st}) (s)		0.45	0.23	
	Peak-overshoot (P_{ov}) (%)		18.5	0	
	Gain margin (dB)		∞	∞	
	Phase margin (deg)		90.0	97.2	
Frequency Characteristics	Over-frequency (Hz)	Test: T ₂ , Fig. 14	50.18	50.04	Over-51 Hz, Under-49 Hz ($\pm 2\%$ of 50 Hz) (DZS 387-1, IEC 61727, IEEE 1547)
		Test: T ₃ , Fig. 16	50.13	50.06	
	Under-frequency (Hz)	Test: T ₂ , Fig. 14	49.84	49.94	
		Test: T ₃ , Fig. 16	49.91	49.94	
	df/dt (Hz/sec)	Test: T ₂ , Fig. 14	+1.82, -1.42 (violated)	+0.61, -0.46	
Voltage Characteristics	dV/dt (V/sec)	Test: T ₂ , Fig. 14	+4.4, -6.6 (violated)	+1.1, -2.6	± 3 V/sec (ANSI 27/59)
	Over-voltage (%)	Test: T ₂ , Fig. 15	4.92	1.19	10% (EN 50160, IEEE 1547.2)
	Under-voltage (%)	Test: T ₂ , Fig. 15	9.05	1.75	
	THD content (%)	Test: T ₂ , Fig. 15	3.30	0.77	5% (IEEE 519, IEEE 929-2000, IEEE 1547)
		Test: T ₃ , Fig. 16	5.37 (violated)	1.21	
	Waveshape	Test: T ₃ , Fig. 16	Huge variation	Smooth	Smooth (IEEE 1547)

Fig. 13 Voltage responses of the RESM as per test case-T₁

response shown in Fig. 13b, it is witnessed that the phase margin is increased from 90° to 97.2° when using the proposed method. This increase in the stability margin boosts the RESM system's stabilization capacity during transients.

Test cases-T₂ and T₃ (of Table 10) are used to analyze the system response during disturbances. For the analysis, various voltage characteristic index [viz., waveshape, rate of change of voltage (dv/dt), over-voltage, under-voltage, total harmonic distortion (THD)] and frequency characteristic index [viz., under-frequency, over-frequency, rate of change of frequency (df/dt)] are obtained. In Test case-T₂, a disturbance of very low frequency (10 Hz) compared to nominal frequency (50 Hz) is injected as shown in Fig. 14a and in Test case-T₃, a nonlinear disturbance of ± 1 pu varying magnitude is injected as shown in Fig. 16a for the comparative study of conventional and proposed methods. From the frequency characteristics given in Figs. 14b and 16b, it is witnessed that the proposed method noticeably decreased the frequency deviation from its rated value compared to the conventional method. Also, from Fig. 14b, it is noticed that the use of conventional method causes a huge df/dt of 1.82 Hz/sec, which exceeds the standard limit of ± 1 Hz/sec as given in Table 11. This is a severe issue that can result in unwanted load shedding or loss of utility-grid connection, concerns with phase balancing, real-power balancing, power hums/electromagnetic interferences for domestic appliances, etc. On the other side, the proposed method reduced the df/dt from 1.82 to 0.61 Hz/sec, which adheres the standard limit of ± 1 Hz/sec. This helps in improving the transient frequency response and can address the majority of the concerns mentioned above. Also, from Fig. 14c, it is noticed that the dv/dt is significantly reduced when using the proposed method.

Fig. 14 Voltage and frequency responses during disturbance as per test case- T_2

As noted in Table 11, the dv/dt obtained with the conventional method violated the standard limit of ± 3 V/sec, which can damage the sensitive electric/electronic devices connected to the system. Similarly, in the 3-phase voltage profile given in Fig. 15a, b, a reactive load disturbance resulted in 4.92% of over-voltage and 9.05% of under-voltage with the conventional method, which got noticeably reduced to 1.19% and 1.75%, respectively, with the proposed method. Control of over/under voltages is very vital as these can transform to high impact swell/sags. Also, from Fig. 16c, d, it is noticed that the conventional method leads to a huge variation in voltage profile for a nonlinear load variation, while, the proposed method improved the voltage profile and

exhibits smooth response. The voltage deviations further lead to harmonic distortion, which is measured as THD [3]. From Figs. 15c and 16e, it is noticed that the proposed method exhibits low THD value of 0.77% and 1.21%, and the conventional method exhibits high THD of 3.30% and 5.37%, respectively, for the reactive and nonlinear load variations. Thus, the conventional method violated the standard limit of 5% as notified in Table 11. Having lower THD, the proposed method helps in preserving the voltage waveform shape during disturbances, which is a critical requisite for the integration of RESM and utility-grid.

6 Conclusions

The fruitful operation of RESMs majorly depends upon the effectiveness of its V/I controllers. It should precisely control such that the system response should recover quickly within allowable tolerances to deliver non-sluggish and safe supply to the sustained load demands in real-time. From the literature, it is observed that even though, there are many controller design methods are available for different applications, their applicability to RESMs is limited as quantified in Sect. 5.1. So, to overcome the demerits of conventional methods and as a new way of controller parameters' design for RESMs application, this paper proposes the MPZC method. The key merits of this method are outlined as follows.

- The proposed method effectively improves the gain margin, which enhances the stabilization capacity of the system when subjected to disturbances.
- The proposed method improves the transient behavior of both voltage and frequency characteristics, as reported in Table 11. This helps to ensure the safety of sensitive loads that are connected to the RESM plant in real-time.
- Improvement of frequency and voltage transient response in the period of key disturbances helps in retaining the supply power quality requisites for the seamless interconnection of RESMs and utility-grid as suggested by IEEE-1547.

Hence, it is concluded that the proposed MPZC method is a better technique to effectively design the V/I controller parameters of RESM plants, which helps to improve the RESM performance in all critical conditions significantly.

Fig. 15 Impact on 3-Phase voltage profile during disturbance as per test case- T_2

Fig. 16 Frequency and voltage responses for test case-T₃

Acknowledgements This work was supported by Project Grant No: SRG/2019/000648, sponsored by the Start-up Research Grant (SRG) scheme of Science and Engineering Research Board (SERB), a statutory body under the Department of Science and Technology (DST), Government of INDIA.

Declarations

Conflict of interest The authors declare they have no conflict of interest.

Open Access This article is licensed under a Creative Commons Attribution 4.0 International License, which permits use, sharing, adaptation, distribution and reproduction in any medium or format, as long as you give appropriate credit to the original author(s) and the source, provide a link to the Creative Commons licence, and indicate if changes were made. The images or other third party material in this article are included in the article's Creative Commons licence, unless indicated otherwise in a credit line to the material. If material is not included in the article's Creative Commons licence and your intended use is not permitted by statutory regulation or exceeds the permitted use, you will need to obtain permission directly from the copyright holder. To view a copy of this licence, visit <http://creativecommons.org/licenses/by/4.0/>.

References

1. Cady ST, Garcia ADD, Hadjicostis CN (2015) A distributed generation control architecture for islanded AC microgrids. *IEEE Trans Control Syst Technol* 23(5):1717–1735
2. Eid BM, Rahim NA, Selvaraj J, Khateb AHE (2016) Control methods and objectives for electronically coupled distributed energy resources in microgrids: a review. *IEEE Syst J* 10(2):446–458
3. Kumar YVP, Bhimasingu R (2017) Electrical machines based DC/AC energy conversion schemes for the improvement of power quality and resiliency in renewable energy microgrids. *Int J Electr Power Energy Syst* 90:10–26
4. Beltran H, Bilbao E, Belenguer E, Otadui IE, Rodriguez P (2013) Evaluation of storage energy requirements for constant production in PV power plants. *IEEE Trans Ind Electron* 60(3):1225–1234
5. Xinda K, Lu N, Jin C (2015) Control and size energy storage systems for managing energy imbalance of variable generation resources. *IEEE Trans Sustain Energy* 6(1):70–78
6. Kerdphol T, Fuji K, Mitani Y, Watanabe M, Qudaih Y (2016) Optimization of a battery energy storage system using particle swarm optimization for stand-alone microgrids. *Int J Electr Power Energy Syst* 81:32–39
7. Ebrahimi J, Babaei E, Gharehpetian GB (2012) A new multilevel converter topology with reduced number of power electronic components. *IEEE Trans Ind Electron* 59(2):655–667
8. Kangarlu MF, Babaei E (2013) A generalized cascaded multilevel inverter using series connection of sub multilevel inverters. *IEEE Trans Power Electron* 28(2):625–636
9. Kumar YVP, Ravikumar B (2016) A simple modular multilevel inverter topology for the power quality improvement in renewable energy based green building microgrids. *Electric Power Syst Res J* 140:147–161

10. Mehra M, Pouresmaeil E, Mehrjerdi H, Jorgensen BN, Catalao JPS (2015) Control technique for enhancing the stable operation of distributed generation units within a microgrid. *Energy Convers Manag* 97:362–373
11. Moradi MH, Eskandari M, Hosseini SM (2016) Cooperative control strategy of energy storage systems and micro sources for stabilizing microgrids in different operation modes. *Int J Electr Power Energy Syst* 78:390–400
12. Tucci M, Rivero S, Vasquez JC, Guerrero JM, Trecate GF (2016) A decentralized scalable approach to voltage control of DC islanded microgrids. *IEEE Trans Control Syst Technol* 24(6):1965–1979
13. Ali B, Davoudi A (2012) Hierarchical structure of microgrids control system. *IEEE Trans Smart Grid* 3(4):1963–1976
14. Li D, Zhu Q, Lin S, Bian XY (2017) A self-adaptive inertia and damping combination control of VSG to support frequency stability. *IEEE Trans Energy Convers* 32(1):397–398
15. Trivedi A, Singh M (2017) Repetitive controller for vsis in droop-based AC-microgrid. *IEEE Trans Power Electron* 32(8):6595–6604
16. Ziegler JG, Nichols NB, Rochester NY (1942) Optimum settings for automatic controllers. *Trans ASME* 64:759–768
17. Murthy BV, Kumar YVP, Kumari UVR (2012) Application of neural networks in process control: automatic/online tuning of PID controller gains for $\pm 10\%$ disturbance rejection. In: *IEEE Int. Conf. on advanced communication control and computing technologies*, pp 348–352
18. Wu H, Su W, Liu Z (2014) PID controllers: design and tuning methods. In: *9th Conf. on industrial electronics & applications*, pp 808–813
19. Shamsuzzoha M (2013) Closed-loop PI/PID controller tuning for stable and integrating process with time delay. *Ind Eng Chem Res* 52(36):12973–12992
20. Bazanella AS, Pereira LFA, Parraga A (2017) A new method for PID tuning including plants without ultimate frequency. *IEEE Trans Control Syst Technol* 25(2):637–644
21. Lee JY, Jin M, Chang PH (2014) Variable PID gain tuning method using backstepping control with time-delay estimation and nonlinear damping. *IEEE Trans Ind Electron* 61(12):6975–6985
22. Dai A, Zhou X, Liu X (2017) Design and simulation of a genetically optimized fuzzy immune PID controller for a novel grain dryer. *IEEE Access* 5:14981–14990
23. Awouda AEA, Mamat RB (2010) Refine PID tuning rule using ITAE criteria. In: *Computer & automation engineering*, Singapore, vol 5, pp 171–176
24. Mallesham G, Mishra S, Jha AN (2011) Ziegler-Nichols based controller parameters tuning for load frequency control in a microgrid. In: *IEEE Int. Conf. on energy, automation, and signal*, Bhubaneswar, India.
25. Grybos P, Szczygiel R (2008) Pole-Zero cancellation circuit with pulse pile-up tracking system for low noise charge-sensitive amplifiers. *IEEE Trans Nucl Sci* 55(1):583–590
26. Chen BS, Hsu YY (2008) A minimal harmonic controller for a STATCOM. *IEEE Trans Ind Electron* 55(2):655–664
27. Tan MT, Chan PK, Lam CK, Ng CW (2010) AC-Boosting frequency compensation with double pole-zero cancellation for multistage amplifiers. *Circuits Syst Signal Process* 29(5):941–951
28. Huang CY, Wang JJ (2010) A pole/zero cancellation approach to reducing forced vibration in end milling. *Int J Mach Tools Manuf* 50(7):601–610
29. Mirhaj SA, Shirazi AN, Ashtiani SJ, Shoaie O (2011) High speed sample and hold design using closed-loop pole-zero cancellation. *Microelectron J* 42(12):1353–1358
30. Seino T, Takahashi I, Ishitsu T, Ueno Y, Kobashi K (2012) An alternative pulse height correction method for pole zero cancellation circuitry. *J Nucl Instrum Methods Phys Res Sect A* 675:133–138
31. Su JT, Liu CW (2012) Gain scheduling control scheme for improved transient response of DC/DC converters. *IET Power Elec* 5(6):678–692
32. Ding C, Zhang W, Jin D, Xie H, Shen P, Chen L (2013) A novel low power UWB cascode SiGe BiCMOS LNA with current reuse and zero-pole cancellation. *AEU-Int J Electron Commun* 67(4):323–328
33. Bayat FM (2013) Fractional-order unstable pole-zero cancellation in linear systems. *J Process Control* 23(6):817–825
34. Yepes AG, Vidal A, Malvar J, Lopez O, Gandoy JD (2014) Tuning method aimed at optimized settling time and overshoot for synchronous proportional-integral current control in electric machines. *IEEE Trans Power Electron* 29(6):3041–3054
35. Golestan S, Monfared M, Freijedo FD, Guerrero JM (2014) Performance improvement of a prefiltered synchronous-reference-frame PLL by using a PID-type loop filter. *IEEE Trans Ind Electron* 61(7):3469–3479
36. Chopade AS, Khubalkar SW, Junghare AS, Aware MV, Das S (2018) Design and implementation of digital fractional order PID controller using optimal pole-zero approximation method for magnetic levitation system. *IEEE/CAA J Automatica Sinica* 5(5):977–989
37. Gianluca G, Palumbo G (2019) In-depth analysis of pole-zero compensations in CMOS operational transconductance amplifiers. *IEEE Trans Circuits Syst I Regul Papers* 66(12):4557–4570
38. Huiliang C, Zhang Y, Han Z (2019) Pole-zero temperature compensation circuit design and experiment for dual-mass MEMS gyroscope bandwidth expansion. *ASME Mechatron* 24(2):677–688
39. Jie Y, Shumin F, Yang QC (2020) Compensation strategies based on Bode step concept for actuator rate limit effect on first-order plus time-delay systems. *Nonlinear Dyn* 99:2851–2866
40. Prasad BS, Jain S, Agarwal V (2008) Universal single-stage grid-connected inverter. *IEEE Trans Energy Convers* 23(1):128–137
41. Wen T, Liu J, Tongwen C, Marquez HJ (2006) Comparison of some well-known PID tuning formulas. *Comput Chem Eng J* 30(9):1416–1423
42. Aidan OD (2009) *Handbook of PI and PID controller tuning rules*, 3rd edn. Imperial College Press

Publisher's Note Springer Nature remains neutral with regard to jurisdictional claims in published maps and institutional affiliations.