

Novel boron-10–based detectors for neutron scattering science^{*}

Helium-3–free detectors for large- and small-area applications: The Multi-Grid and the Multi-Blade prototypes

Francesco Piscitelli^{1,2,3,a,b}

¹ Institut Laue-Langevin (ILL), 6, Jules Horowitz, 38042 Grenoble, France

² European Spallation Source (ESS AB), P.O. Box 176, SE-221 00 Lund, Sweden

³ Department of Physics, University of Perugia, Piazza Università 1, 06123 Perugia, Italy

Received: 22 October 2014 / Revised: 29 December 2014

Published online: 13 February 2015

© The Author(s) 2015. This article is published with open access at Springerlink.com

Abstract. Nowadays neutron scattering science is increasing its instrumental power. Most of the neutron sources in the world are pushing the development of their technologies to be more performing. The neutron scattering development is also pushed by the European Spallation Source (ESS) in Sweden, a neutron facility which has just started construction. Concerning small-area detectors ($\sim 1\text{ m}^2$), the ^3He technology, which is today cutting edge, is reaching fundamental limits in its development. Counting rate capability, spatial resolution and cost effectiveness, are only a few examples of the features that must be improved to fulfill the new requirements. On the other hand, ^3He technology could still satisfy the detector requirements for large-area applications ($\sim 50\text{ m}^2$), however, because of the present ^3He shortage that the world is experiencing, this is not practical anymore. The recent detector advances (the Multi-Grid and the Multi-Blade prototypes) developed in the framework of the collaboration between the Institut Laue-Langevin (ILL) and ESS are presented in this paper. In particular two novel ^{10}B -based detectors are described; one for large-area applications (the Multi-Grid prototype) and one for application in neutron reflectometry (small-area applications, the Multi-Blade prototype).

1 Introduction

Neutron scattering science is increasing its instrumental power and consequently improved performance are requested to the detection systems. In particular the upcoming neutron facility ESS will need a first suite of instruments fully operational already in 2019 [1]. The peak brightness at the ESS will be higher than that of any of the existing short pulse sources and it will be one order of magnitude higher than that of the world's leading continuous source. The time-integrated brightness at ESS will also be one or two orders of magnitude larger than at leading pulsed sources today. ESS will be a long pulse source, with an average beam power of 5 MW delivered to the target station. Figure 1 shows the expected pulse of ESS compared to the pulses of existing spallation sources in the world and to the steady flux available at reactor sources.

^3He gaseous detectors and scintillating detectors are the two principal technologies employed in thermal and cold neutron detection in all the facilities, at present, for any kind of instrument. These technologies are already close to the cutting-edge development which is sufficient to assure the performance of the instruments in neutron facilities at present. The needs of future neutron scattering science, including those of ESS, cannot be met with today's technologies if further studies and developments are performed [2–4].

Because of the shortage of ^3He [5–7], it is crucial to find an alternative, efficient and cost-effective way to detect thermal and cold neutrons for large-area applications ($\sim 50\text{ m}^2$), *e.g.* chopper spectrometers like IN5 [8] at ILL.

^{*} Contribution to the Focus Point on “ ^3He replacement in neutron detection: Current status and perspectives” edited by N. Colonna, A. Pietropaolo, F. Sacchetti.

^a On behalf of the ILL/ESS/LiU Collaboration for the development of the B10 detector technology in the framework of the CRISP project.

^b e-mail: francesco.piscitelli@ess.se




Fig. 1. The ESS long pulse compared to the pulses of existing spallation sources in the world and to the steady flux available at reactor sources [1].

Table 1. Detectors features on instruments at existing facilities, where figures are publically available.

Instrument	Facility	Active area (m × m)	Spatial res. (mm × mm)	Efficiency	Global rate (s ⁻¹)	Local rate (s ⁻¹ cm ⁻²)
Chopper spectrometers						
IN5 [8]	ILL	10 × 3	26 × 26	~ 74% @ 1.8 Å	–	–
Reflectometers						
FIGARO [9]	ILL	0.5 × 0.25	2 × 7.5	~ 63% @ 2.5 Å	3 · 10 ⁷	23 · 10 ³
INTER [10]	ISIS	0.2 × 0.2	1 × 1	–	–	–

Table 2. Summary of generalized detector requirements for chopper spectrometers and reflectometers at ESS.

ESS instrument type	Active area (m ²)	Wavelength band (Å)	Spatial resolution (mm × mm)	Time resolution (μs)	Max flux at sample (s ⁻¹ cm ⁻²)
Chopper spectrometers [11]	50	[0.8, 20]	20 × 20	10	10 ⁷
Reflectometers [12]	~ 1	[2, 23]	0.5 × 2	100	10 ⁹

Even though a limited quantity of ³He would be available for small-area detectors (~ 1 m²), the requirements for the future detectors cannot be fulfilled by this technology. The main goal to be achieved for small-area applications is to expand the detector performance mostly in terms of counting rate capability and spatial resolution, as well as cost effectiveness. The development of small-area detectors is focused on reflectometry applications, which is where the requirements are more challenging.

In table 1 the features of the state-of-the-art detector technology at existing facilities for chopper spectrometers and reflectometers are summarized.

Table 2 summarizes the requirements at ESS for large-area detectors for chopper spectrometers and for small-area detectors for reflectometry applications. The flux at sample must be also interpreted as the maximum rate the detector should tolerate. It is not unlikely that the full beam is completely reflected toward the detector in a neutron reflectometry experiment.

The Multi-Grid [13,14] prototype has been developed in the framework of the collaboration between ILL and ESS in order to address the problem of the ³He shortage for large-area detectors. It is a gaseous detector that contains 30 ¹⁰B₄C layers as neutron converters. Each neutron can be converted in one of these layers that are crossed orthogonally by the neutron beam. Several prototypes using the Multi-Grid design have been built and tested, showing the feasibility of such a design for large-area coverage with a suitable neutron detection efficiency.

On the other hand, the Multi-Blade [15,16] prototype, already introduced at ILL in 2005 [17], is a small-area detector which aims at pushing the limits of spatial resolution beyond that of ³He-based detectors for high flux applications. In particular it has been conceived to be suitable for neutron reflectometry instruments, though potential applications could be broader than that. A detailed study on this prototype has been carried out at ILL showing the improvements in terms of detector features of such a design.

The Multi-Grid and the Multi-Blade prototypes are described and the results are illustrated in the following sections.




Fig. 2. A picture of the vacuum chamber of IN5 at ILL equipped with ^3He tubes (left). A drawing of the Multi-Grid $3 \times 0.8\text{m}^2$ area demonstrator nearby the ^3He detectors of the instrument (right).




Fig. 3. Expected efficiency as a function of the neutron wavelength for a detector made up of 2, 10, 28, 30 and 34 $^{10}\text{B}_4\text{C}$ layers. The converter thickness is $1\ \mu\text{m}$ for all the layers in the plot on the left and $0.5\ \mu\text{m}$ for the plot on the right. The contribution of the Al scattering from substrates and detector window is also taken into account.

2 Large-area applications: The Multi-Grid prototype

Several versions of the Multi-Grid detector have been implemented at ILL in collaboration with ESS in the framework of the CRISP project (<http://www.crisp-fp7.eu/>). With the construction of these prototypes the reliability and the actual performance of this design have been shown. A new prototype of $3 \times 0.8\text{m}^2$ active area is being built to demonstrate the feasibility of a large-area detector for neutron chopper spectrometers, *e.g.* IN5 at ILL [8]. The IN5 Time-of-Flight spectrometer is used as a benchmark for performance and geometry requirements. IN5 was chosen for its size of about $\sim 30\text{m}^2$. It is the largest chopper spectrometer at ILL, finding a replacement for ^3He -based detectors over such a surface is the main goal to validate the feasibility of large areas detectors based on $^{10}\text{B}_4\text{C}$. The Multi-Grid design must be able to cover a sensitive area above 30m^2 with about $2 \times 2\text{cm}^2$ spatial resolution. Figure 2 shows a picture of the vacuum chamber of IN5 equipped with 12×32 ^3He tubes and a drawing of the $3 \times 0.8\text{m}^2$ area demonstrator nearby the ^3He detectors of the actual instrument.

A Multi-Grid is a proportional gaseous detector in which the neutron conversion into charged particles is obtained by using solid $^{10}\text{B}_4\text{C}$ layers. ^{10}B was chosen as the neutron converter because of its large absorption cross-section for thermal neutrons ($\sigma_{\text{abs}} = 3838\text{b}$), and relatively high energy of its reaction products [13]. In the actual prototype the $^{10}\text{B}_4\text{C}$ was chosen due to its conductivity, thermal and chemical stability compared to pure ^{10}B . Due to the limited efficiency that can be achieved with a single layer [18] (if it is not operated under a grazing angle as it is in the Multi-Blade concept [16]), many layers are necessary to reach a suitable detection efficiency. If a single layer is used a grazing angle must be operated because the neutron absorption path in the layer travels closer to the surface. Consequently the neutron capture fragments have higher chances to escape the layer and thus to contribute to the efficiency. At a normal incidence a single layer is only about 5% efficient at thermal energies.




Fig. 4. A drawing of a frame where $^{10}\text{B}_4\text{C}$ -coated blades are inserted (left) and fully assembled grid (frame and blades) of the prototype (right).

An optimization of the layer thicknesses, the number of layers necessary, and considerations on the substrate effects are required as well as a minute mechanical study. According to [19], in order to get a detection efficiency around 50%, while keeping the mechanics reasonably simple, a good choice for the number of layers is around 30. The optimal thickness of the layers should be fixed at $1\ \mu\text{m}$ if we consider a monochromatic neutron beam at $2.5\ \text{\AA}$ [19]. The interesting neutron wavelength range for the scientific case of chopper spectrometer instruments is about from $1\ \text{\AA}$ to $20\ \text{\AA}$ which corresponds to energies from $82\ \text{meV}$ to $200\ \mu\text{eV}$. Further optimization is possible if there are requirements on a particular neutron wavelength distribution or efficiency. It has been shown in [19] that a reasonable optimization is the one that considers the barycenter of the wanted neutron wavelength distribution, *i.e.* the $2.5\ \text{\AA}$ will provide a detector optimized for short wavelengths. Figure 3 shows the expected efficiency as a function of wavelength for a detector made up of 2, 10, 28, 30 and 34 $^{10}\text{B}_4\text{C}$ layers, in the two cases in which all the layers are $1\ \mu\text{m}$ or $0.5\ \mu\text{m}$ thick. The detector with $0.5\ \mu\text{m}$ layers is optimized for long wavelengths. The contribution given by the scattering or absorption in the aluminium substrates ($0.5\ \text{mm}$ thick) is also taken into accounts in the plots in fig. 3, as well as a $2.5\ \text{mm}$ entrance Al window. The decreasing efficiency at longer wavelengths is due to the absorption of neutrons by the detector entrance Al window. No decrease can be observed if the entrance window is neglected.

Several prototypes made up of 28 and 30 layers have been built and tested. A 34-layer detector of large area is under construction.

A Multi-Grid detector is composed of a gas vessel filled with grids electrically insulated one from another and stacked to make square or rectangular counters [14], *i.e.* tubes. Each grid is made up of a frame in which blades, coated with $^{10}\text{B}_4\text{C}$ [20] on both sides, are inserted (see fig. 4). Both the frame and the blades are made of aluminium, which has a low scattering and absorption cross-section for neutrons [21].

The grids, stacked one after the other, act as a segmented cathode (see figs. 5 and 6). The readout is performed by the cathode grids and anode wires. Each of these anode wires is placed in the middle of a tube formed by the stacked grids. Individual and charge division readouts have both been implemented. The grids are electrically insulated and each of them is connected to a charge amplifier. Each anode wire is either connected directly to a charge amplifier (individual readout) or is connected to the other wires through resistors. This allows to readout many wires with only two charge amplifiers connected at the ends of the resistive chain. The position of the neutron interaction point is reconstructed by the coincidence between grid and wire signals.

Figure 6 shows two of the assembled Multi-Grid prototypes. Both of them used 28 converter layers. The first, with its 96 grids, had an active area of $0.08 \times 2\ \text{m}^2$ [21–23], and the second demonstrator of about $0.3 \times 0.5\ \text{m}^2$. The second prototype [24] was installed on the Time-of-Flight chopper spectrometer IN6 [30] at ILL placed side by side to the conventional ^3He detectors of the instrument.

The detector was tested with both an Ar/CO_2 (90 : 10) gas mixture and CF_4 [21]. Counting curves and Pulse Height Spectra (PHS) have been measured for several different stopping gas pressures in order to confirm that the detector can be operated at either atmospheric pressure or even below.

The neutron detection efficiency was measured on our test beam line at ILL, CT2, with a monochromatic neutron beam of $2.5\ \text{\AA}$. As shown in [13], an ^3He -multi-tube detector was used as a reference and an efficiency of $(46.8 \pm 0.3)\%$ was found for the detector with 28 converter layers. The position resolution was also measured and it resulted to be $2 \times 2\ \text{cm}^2$. This resolution is given by the size of the voxel identified by a single grid and a wire (see fig. 5). It has been proved that a finer spatial resolution can be obtained by calculating the center of gravity of the induced charge on adjacent grids.

The 96-grids detector was scanned in order to quantify the uniformity in the efficiency. It has been already proven [20], that the $^{10}\text{B}_4\text{C}$ coatings show about a 13% variation in thickness due to the deposition method, this affects the detector uniformity in the range of 1% [13].




Fig. 5. The grids are stacked to form rectangular tubes where an anode wires are inserted.




Fig. 6. A 96-grid prototype of active area $0.08 \times 2 \text{ m}^2$ is shown on the left, during its construction. A $0.3 \times 0.5 \text{ m}^2$ prototype is shown on the right.

An accurate study on the response of the Multi-Grid detector in presence of γ -ray background is reported in [31]. A high level of discrimination between neutron and photon signals can be reached with ^3He detectors. The sensitivity of a neutron detector to γ -rays is a very important characteristic, as it defines the best achievable signal-to-noise ratio. In a neutron facility the γ -ray background is produced by the interaction of the neutrons with the parts of the instrument. Neutron guides, collimators, shielding, beam stoppers and choppers, are only a few of the objects where a neutron can be absorbed giving rise to γ -ray background. The majority of efficient neutron absorbers, in particular ^{10}B , ^{113}Cd , ^{115}Cd and ^{157}Gd , emit one or more γ -rays for each neutron captured. The energy of these γ -rays span a very wide range that goes from a few tens of keV up to about 10 MeV. Considering that the scattering cross-sections of many samples tend to be relatively low, the neutron intensity that carries useful information can be many orders of magnitude lower than the flux of γ -rays [31].

The physical effects and geometric considerations that affect the sensitivity to γ -rays in gas-based detectors for thermal neutrons have been deeply investigated. It has been found that the γ -ray rejection do not need to be lower in ^{10}B -based detectors than in ^3He tubes. A correctly chosen energy threshold and operating voltage allow for an equally high γ -ray rejection as in a ^3He detector. In particular for the Multi-Grid detector, it has been shown that sensitivities below 10^{-6} can be reached by setting an energy threshold to 100 keV and operating the Multi-Grid at 900 V. At this voltage the equivalent gas gain is below 100, consequently γ -rays can be discriminated by their energy and only losing a few percent in the neutron detection efficiency.




Fig. 7. A drawing of the Multi-Blade detector, several identical units (cassettes) are aligned to form a detector. Each module is an independent MWPC.

With the Multi-Grid demonstrator, installed on IN6 in order to be tested in a real instrument environment, it has been shown the suitable Time-of-Flight resolution of the ^{10}B -based detector as well as its better solid angle coverage with respect to ^3He tubes. Considering the dead spaces, *i.e.* solid angle coverage of the Multi-Grid detector, this is only 3% less efficient than the IN6 detection system at 4.6 Å and 9% more efficient at 4.1 Å [24].

During the tests on IN6 it became clear that not only γ -ray and neutron background was present: the detector showed a count rate that could not be correlated neither to γ -ray or neutron events. This background was not modulated when the beam was pulsed and was present irrespective of the instrument's shutter state or even the reactor operation. The found the source of such background are the naturally occurring concentrations of uranium and thorium in aluminium [25]. The concentration of radioisotopes in materials [26] is a well known topic in the the chemical industry and it has also been investigated in the field of the neutron detectors [27]. Two solutions are currently being investigated to eliminate this background. One is to deposit a thin nickel layer at the surface of aluminium in order stop the alpha particles before they reach the gas [28]. The other solution is to use U/Th-free aluminium for which the concentration of uranium and thorium is 2–3 orders of magnitude lower than in standard aluminium alloys [29]. Both this solutions reduce the background of several order of magnitudes. Respective costs will likely be the deciding factor between these two approaches.

The following step in this project is the construction of the $3 \times 0.8 \text{ m}^2$ large-area demonstrator. This detector will demonstrate the feasibility and cost of large-scale production of both the mechanical parts as well as the $^{10}\text{B}_4\text{C}$ layers required [24].

3 Small-area applications: The Multi-Blade prototype

The Multi-Blade prototype [16] is a small-area detector for neutron reflectometry applications [9]. Although the amount of ^3He needed for a small-area detector will be available in the future, the Multi-Blade wants to push the limit of ^3He -based detectors in terms of spatial resolution and counting rate capability. The Multi-Blade is a Multi Wire Proportional Chamber (MWPC) operated at atmospheric pressure (see fig. 7). This detector uses $^{10}\text{B}_4\text{C}$ converters at grazing angle with respect to the incoming neutron beam. The angled geometry improves both its spatial resolution and its counting rate capability. The use of the $^{10}\text{B}_4\text{C}$ conversion layer at grazing angle also increases the detection efficiency.

The Multi-Blade prototype is conceived to be modular in order to be adaptable to different applications. A significant concern in a modular design is the uniformity of the detector response. Several effects might contribute to degrade the uniformity and they have to be taken into account in the detector concept: overlap between different substrates, coating uniformity, substrate flatness and parallax errors.




Fig. 8. Schematic of the Multi-Blade detector made up of several independent and identical units called *cassettes* (left). A picture of the Multi-Blade prototype composed of 4 *cassettes* (right).

Each module of the Multi-Blade, a so-called *cassette*, is an independent MWPC equipped with the neutron converter and a two-dimensional readout system. Wires are placed orthogonally to cathode strips (see fig. 7); the interaction point of the neutron is reconstructed by the coincidence wires and strips.

The fully assembled detector is composed of several cassettes as shown in the schematic in fig. 8.

Several approaches in the prototype design have been studied: number of converters, read-out system and materials to be used. Two versions of the Multi-Blade prototype have been built focusing on its different issues and features. Their detection efficiency and uniformity were measured on the test beam line CT2 at ILL. It has been shown in [16] that a suitable detection efficiency for reflectometry applications can be achieved with such a detector. The main issue in the Multi-Blade design is the uniformity over its active surface. The cassettes overlap to avoid dead zones, and, in the switching between one cassette to another, a loss in efficiency can occur. Further studies are necessary to optimize the detector uniformity.

The detector is operated at atmospheric pressure. This makes it suitable to be operated in vacuum chambers. Moreover, cost effective materials can be used inside the detector because outgassing is not an issue. The materials used in the detector can pour out molecules that give rise to radicals. The presence of radicals in the gas drastically affects the detector functionality and aging. Since the gas is flushed those molecules are continuously evacuated.

The spatial resolution was measured [16] to be $0.275 \times 4 \text{ mm}^2$. The reasonable limit in the resolution that can be reached with ^3He detectors is around 1 mm. In many areas of soft and hard matter research science, the amount of material to investigate is rather limited. Partly because the fabrication of larger samples is too expensive or not feasible, yet, partly because the interesting features depend on the size. The development of a neutron reflectometer optimized for small samples is under study [32,33]. There is a great interest in expanding the technique of neutron reflectometry beyond static structural measurements of layered structures to kinetic studies [34]. In order to perform these studies the neutron wavelength to position encoding is necessary [35], but, due to the practical limits in the actual spatial resolution of ^3He -based detectors this concept is probably not practical. Therefore, the development of an area detector with 0.2 mm, required in one dimension only, is crucial [34]. The Multi-Blade can easily fulfill this requirement. The Multi-Blade concept is a promising alternative, to accomplish the high spatial resolution and the high counting rate capability which is in principle 10 times higher than conventional ^3He -based detectors [16].

4 Conclusions

The Multi-Grid concept has been successfully introduced and tested. It has been shown, with the construction of several prototypes, that the performance of such a design fulfills the needs of the instruments that requires large area detectors, *i.e.* chopper spectrometers. A neutron detection efficiency of about 50% at 2.5 \AA can be reached with 30 $^{10}\text{B}_4\text{C}$ layers [13]. This detector is operated at atmospheric pressure with a continuous gas flow. This makes this detector suitable to be operated in vacuum chambers as well as the cost-effectiveness of the materials that can be used.

A $0.3 \times 0.5 \text{ m}^2$ area demonstrator [24] has been tested in the Time-of-Flight chopper spectrometer IN6 at ILL placed side by side to the conventional ^3He detectors of the instrument. The suitable Time-of-Flight resolution of the ^{10}B -based detector as well as its better solid angle coverage with respect to ^3He tubes have been shown. U/Th-free aluminium and nickel plating of aluminium have been investigated as the two solutions to reduce the natural α -emission of Al contaminants. Background is efficiently reduced and the respective costs will be the deciding factor between these two approaches.

Although the Multi-Grid detector efficiency is smaller than for ^3He detectors, it can be considered suitable in the context of the ^3He shortage. In addition to that, it has been shown that the wider solid angle coverage of the Multi-Grid design, *i.e.* its higher granularity, with respect to the ^3He detectors, adequately compensates this smaller efficiency [24].

An accurate study on the γ -ray sensitivity of such a technology has been performed to validate its reliability in terms of background γ -ray rejection [31].

A prototype of $3 \times 0.8 \text{ m}^2$ and exploiting 34 layers is under construction. The expected efficiency is about 56% for 2.5 Å. This prototype will demonstrate the feasibility of a large-area detector that can be scaled up to a few tens of square meters.

In order to tackle the problem of the limitations of the ^3He technology in terms of counting rate capability and spatial resolution for small-area detector, the Multi-Blade prototype has been built and tested [16]. In particular a high spatial resolution detector based on inclined $^{10}\text{B}_4\text{C}$ layers suitable for neutron reflectometry instruments has been developed. This detector has been conceived to be modular in order to be more versatile: it is composed of modules called *cassettes*. All the issues that can arise from a modular design have been investigated. The detector is operated at atmospheric pressure. This makes it suitable to be operated in vacuum. Moreover, cost effective materials can be used inside the detector because outgassing is not an issue. It has been shown that a proper detection efficiency for reflectometry instruments can be achieved with such a detector. The presented Multi-Blade prototype showed a very high spatial resolution, it was measured to be about $0.3 \times 4 \text{ mm}^2$ [16].

Throughout the design, assembly and characterization of our ^{10}B -based prototypes, it has been shown that this technology is a viable replacement of the sparse ^3He , in terms of performance and cost. This ^{10}B detector technology will certainly form a central part of the landscape for future detectors for neutron scattering instruments.

The work has been supported by the CRISP project (European Commission 7th Framework Programme Grant Agreement 283745), <http://www.crisp-fp7.eu/>.

Open Access This is an open access article distributed under the terms of the Creative Commons Attribution License (<http://creativecommons.org/licenses/by/4.0>), which permits unrestricted use, distribution, and reproduction in any medium, provided the original work is properly cited.

References

1. S. Peggs, *ESS Technical Design Report*, ESS-doc-274 (2013).
2. B. Gebauer *et al.*, Nucl. Instrum. Methods A **535**, 65 (2004).
3. R. Cooper *et al.*, *A program for neutron detector research and development*, in *Proceedings of the Workshop Held at Oak Ridge National Laboratory July 12-13, 2002* (2003).
4. R. Hall-Wilton *et al.*, *Detectors for the European Spallation Source*, in *Nuclear Science Symposium and Medical Imaging Conference (NSS/MIC) Anaheim, IEEE TNS* (2012) pp. 4283–4289.
5. D.A. Shea, D. Morgan, *The Helium-3 Shortage: Supply, Demand, and Options for Congress*, Congressional Research Service, 22 December 2010.
6. R.T. Kouzes, *The ^3He Supply Problem*, Technical Report **11-753**, US Government Accountability Office 2011.
7. K. Zeitelhack, Neutron News **23**, 10 (2012).
8. J. Ollivier *et al.*, Neutron News **21**, 22 (2010).
9. R.A. Campbell *et al.*, Eur. Phys. J. Plus **126**, 107 (2011).
10. J. Webster *et al.*, Physica B **385-386**, 1164 (2006).
11. T-REX Proposal, submitted for consideration, ESS instrument proposal round 2013-4.
12. FREIA - ESS Instrument Construction Proposal 2013.
13. J. Birch *et al.*, IEEE Trans. Nucl. Sci. **60**, 871 (2013).
14. Patent no. 20110215251.
15. J.C. Buffet *et al.*, *Study of a ^{10}B -based Multi-Blade detector for Neutron Scattering Science*, in *Nuclear Science Symposium and Medical Imaging Conference (NSS/MIC) Anaheim, IEEE TNS* (2012) pp. 171-175.
16. F. Piscitelli *et al.*, JINST **9**, P03007 (2014).
17. J.C. Buffet *et al.*, Nucl. Instrum. Methods A **554**, 392 (2005).
18. D.S. McGregor *et al.*, Nucl. Instrum. Methods A **500**, 272 (2003).
19. F. Piscitelli *et al.*, JINST **8**, P04020 (2013).
20. C. Höglund *et al.*, J. Appl. Phys. **111**, 10490 (2012).
21. K. Andersen *et al.*, Nucl. Instrum. Methods A **720**, 116 (2012).
22. T. Bigault *et al.*, Neutron News **23**, 20 (2012).
23. A. Khaplanov *et al.*, *Multi-Grid Boron-10 detector for large area applications in neutron scattering science*, arXiv:1209.0566 (2012).

24. J. Birch *et al.*, J. Phys.: Conf. Ser. **528**, 012040 (2014).
25. F.F. Dyer *et al.*, J. Radioanal. Chem. **72**, 53 (1982) *Determination of uranium and thorium in semiconductor memory materials by high fluence neutron activation analysis*, presented at the Sixth International Conference, Modern Trends in Activation Analysis (1981), University of Toronto, CA.
26. J. Hofmann *et al.*, *Natural Radionuclide Concentrations in Materials Processed in the Chemical Industry and the Related Radiological Impact*, European Commission Report EUR 19264 (2000).
27. K. Zeitelhack, *Investigation of ^3He Proportional Counters for Neutron Detection made from Ni-coated Aluminium tubes*, Internal Report Detectorlab FRM-II (2001).
28. Praxair - Surface technologies, <http://www.praxairsurfacetechologies.com/>.
29. Norsk Hydro ASA - Aluminium metal and aluminium products, <http://www.hydro.com/>.
30. Y. Blanc, *Le Spectrometre a temps de vol IN6*, ILL report **83BL21G** (1983).
31. A. Khaplanov *et al.*, JINST **8**, P10025 (2013).
32. J. Stahn *et al.*, Eur. Phys. J. Appl. Phys. **58**, 11001 (2012).
33. Reflectometry instruments. ESS Instrument Construction Proposal round 2013.
34. R. Cubitt *et al.*, Eur. Phys. J. Plus **126**, 111 (2011).
35. R. Cubitt *et al.*, Nucl. Instrum. Methods A **558**, 547 (2006).