Advances in Industrial Control

Springer-Verlag London Ltd.

Other titles published in this Series:

Feedback Control Theory for Dynamic Traffic Assignment

Pusjkin Kachroo and Kaan Özbay

Robust Aeroservoelastic Stability Analysis

Rick Lind & Marty Brenner

Performance Assessment of Control Loops: Theory and Applications

Biao Huang & Sirish L. Shah

Advances in PID Control

Tan Kok Kiong, Wang Qing-Guo & Hang Chang Chieh with Tore J. Hägglund

Advanced Control with Recurrent High-order Neural Networks: Theory and Industrial Applications

George A. Rovithakis & Manolis A. Christodoulou

Structure and Synthesis of PID Controllers

Aniruddha Datta, Ming-Tzu Ho and Shankar P. Bhattacharyya

Data-driven Techniques for Fault Detection and Diagnosis in Chemical Processes

Evan L. Russell, Leo H. Chiang and Richard D. Braatz

Bounded Dynamic Stochastic Systems: Modelling and Control

Hong Wang

Non-linear Model-based Process Control

Rashid M. Ansari and Moses O. Tadé

Identification and Control of Sheet and Film Processes

Andrew P. Featherstone, Jeremy G. VanAntwerp and Richard D. Braatz

Precision Motion Control

Tan Kok Kiong, Lee Tong Heng, Dou Huifang and Huang Sunan

Nonlinear Identification and Control: A Neural Network Approach

Guoping Liu

Digital Controller Implementation and Fragility: A Modern Perspective

Robert S.H. Istepanian and James F. Whidborne

Optimisation of Industrial Processes at Supervisory Level

Doris Sáez, Aldo Cipriano and Andrzej W. Ordys

Applied Predictive Control

Huang Sunan, Tan Kok Kiong and Lee Tong Heng

Hard Disk Drive Servo Systems

Ben M. Chen, Tong H. Lee and Venkatakrishnan Venkataramanan

Robust Control of Diesel Ship Propulsion

Nikolaos Xiros

Hydraulic Servo-Systems

Mohieddine Jelali and Andreas Kroll

Silvio Simani, Cesare Fantuzzi
and Ron J. Patton

Model-based Fault Diagnosis in Dynamic Systems Using Identification Techniques

Springer

Silvio Simani, PhD

Dipartimento di Ingegneria, Università di Ferrara, Via Saragat, 1. 44100 Ferrara, Italia

Cesare Fantuzzi, PhD

Dipartimento di Scienze per l'Ingegneria, Università di Modena e Reggio Emilia, Italia

Ronald Jon Patton, Beng, MEng, PhD

School of Engineering, The University of Hull, Cottingham Road, Kingston-Upon-Hull, HU6 7RX, UK

ISBN 978-1-84996-895-9 ISBN 978-1-4471-3829-7 (eBook)

DOI 10.1007/978-1-4471-3829-7

British Library Cataloguing in Publication Data

Simani, Silvio

Model-based fault diagnosis in dynamic systems using identification techniques. - (Advances in industrial control)

1.Feedback control systems - Mathematical models 2.Fault location (Engineering) - mathematical models 3.System identification

I.Title II.Fantuzzi, Cesare III.Patton, Ron, 1949- 629.8'015118

Library of Congress Cataloging-in-Publication Data

A catalog record for this book is available from the Library of Congress.

Apart from any fair dealing for the purposes of research or private study, or criticism or review, as permitted under the Copyright, Designs and Patents Act 1988, this publication may only be reproduced, stored or transmitted, in any form or by any means, with the prior permission in writing of the publishers, or in the case of reprographic reproduction in accordance with the terms of licences issued by the Copyright Licensing Agency. Enquiries concerning reproduction outside those terms should be sent to the publishers.

<http://www.springer.co.uk>

© Springer-Verlag London 2003

Originally published by Springer-Verlag London Limited in 2003.

Softcover reprint of the hardcover 1st edition 2003

MATLAB® is the registered trademarks of The MathWorks Inc., 3 Apple Hill Drive Natick, MA 01760-2098, U.S.A. <http://www.mathworks.com>

The use of registered names, trademarks etc. in this publication does not imply, even in the absence of a specific statement, that such names are exempt from the relevant laws and regulations and therefore free for general use.

The publisher makes no representation, express or implied, with regard to the accuracy of the information contained in this book and cannot accept any legal responsibility or liability for any errors or omissions that may be made.

Typesetting: Electronic text files prepared by authors

69/3830-543210 Printed on acid-free paper SPIN 10830790

Advances in Industrial Control

Series Editors

Professor Michael J. Grimble, Professor of Industrial Systems and Director
Professor Michael A. Johnson, Professor of Control Systems and Deputy Director

Industrial Control Centre
Department of Electronic and Electrical Engineering
University of Strathclyde
Graham Hills Building
50 George Street
Glasgow G1 1QE
United Kingdom

Series Advisory Board

Professor E.F. Camacho
Escuela Superior de Ingenieros
Universidad de Sevilla
Camino de los Descubrimientos s/n
41092 Sevilla
Spain

Professor S. Engell
Lehrstuhl für Anlagensteuerungstechnik
Fachbereich Chemietechnik
Universität Dortmund
44221 Dortmund
Germany

Professor G. Goodwin
Department of Electrical and Computer Engineering
The University of Newcastle
Callaghan
NSW 2308
Australia

Professor T.J. Harris
Department of Chemical Engineering
Queen's University
Kingston, Ontario
K7L 3N6
Canada

Professor T.H. Lee
Department of Electrical Engineering
National University of Singapore
4 Engineering Drive 3
Singapore 117576

Professor Emeritus O.P. Malik
Department of Electrical and Computer Engineering
University of Calgary
2500, University Drive, NW
Calgary
Alberta
T2N 1N4
Canada

Professor K.-F. Man
Electronic Engineering Department
City University of Hong Kong
Tat Chee Avenue
Kowloon
Hong Kong

Professor G. Olsson
Department of Industrial Electrical Engineering and Automation
Lund Institute of Technology
Box 118
S-221 00 Lund
Sweden

Professor A. Ray
Pennsylvania State University
Department of Mechanical Engineering
0329 Reber Building
University Park
PA 16802
USA

Professor D.E. Seborg
Chemical Engineering
3335 Engineering II
University of California Santa Barbara
Santa Barbara
CA 93106
USA

Doctor I. Yamamoto
Technical Headquarters
Nagasaki Research & Development Center
Mitsubishi Heavy Industries Ltd
5-717-1, Fukahori-Machi
Nagasaki 851-0392
Japan

SERIES EDITORS' FOREWORD

The series *Advances in Industrial Control* aims to report and encourage technology transfer in control engineering. The rapid development of control technology has an impact on all areas of the control discipline. New theory, new controllers, actuators, sensors, new industrial processes, computer methods, new applications, new philosophies..., new challenges. Much of this development work resides in industrial reports, feasibility study papers and the reports of advanced collaborative projects. The series offers an opportunity for researchers to present an extended exposition of such new work in all aspects of industrial control for wider and rapid dissemination.

As many technological systems become more complex, widespread and integrated, the effects of system failure can be simply devastating to the infrastructure of modern society. Feedback control is just one important component of total system supervision. Fault detection and isolation (FDI) is a second component with extensive commercial, industrial and societal implications if only we could work out how to do it in a reliable and inexpensive manner. Hardware or physical redundancy is the usual solution of the practical FDI problem, but as the authors Simani, Fantuzzi and Patton note in this monograph it is capital and maintenance costly. The search for reliable and inexpensive FDI methods has been active since the early 1970s. Since 1991, the International Federation of Automatic Control (IFAC) has created the SAFEPROCESS Steering Committee to promote research, developments and applications in the FDI field. The last decade has seen the formalisation of several theoretical approaches accompanied by some attempts to standardise nomenclature in the field.

The monograph series *Advances in Industrial Control* does not have many entries from this important research area but the monograph by Mangoubi, *Robust Estimation and Failure Detection* (ISBN 3-540-76251-5; 1998) and that by Russell, Chiang and Braatz, *Data-driven Techniques for Fault Detection and Diagnosis in Chemical Processes* (ISBN 1-85233-285-1; 2000) both make contributions even if they use quite different ideas. To these we can now add this monograph by S. Simani, C. Fantuzzi and R.J. Patton. Key features of this text include useful survey material (Chapter 2), a new approach based on model identification and an extended application study using a single shaft industrial gas turbine (Chapter 5). Different groups of readers ranging from industrial engineers wishing to gain insight into the applications potential of new FDI methods, to the academic control community looking for new problems to tackle (Chapter 6) will find much to learn from this monograph.

M.J. Grimble and M.A. Johnson
Industrial Control Centre
Glasgow, Scotland, U.K.

PREFACE

Control devices, which are nowadays exploited to improve the overall performance of industrial processes, involve both sophisticated digital system design techniques and complex hardware (input-output sensors, actuators, components and processing units). Such complexity results in an increased probability of failure. As a direct consequence of this, control systems must include automatic supervision of the closed-loop operation to detect and isolate malfunctions as early as possible.

Since the early 1970s, the problem of fault detection and isolation (FDI) in dynamic processes has received great attention, and a large variety of methodologies have been studied and developed based upon both physical and analytical redundancy. In the first case, the system is equipped with redundant physical devices, like sensors and actuators, so that if a fault occurs, the redundant device replaces the functionality of the faulty one.

The analytical redundancy approach is based on a completely different principle. The basic idea consists of using an accurate model of the system to mimic the real process behaviour. If a fault occurs, the residual signal (*i.e.* the difference between real system and model behaviours) can be used to diagnose and isolate the malfunction. This approach has some advantages with respect to physical (hardware-software) redundancy, mainly in economical and practical aspects. The analytical redundancy approach does not require additional equipment, but also suffers from some potential disadvantages, which are principally related to the need of an accurate model of the real system.

Model-based method reliability, which also includes false alarm rejection, is strictly related to the “quality” of the model and measurements exploited for fault diagnosis, as model uncertainty and noisy data can prevent an effective application of analytical redundancy methods.

This is not a simple problem. As model-based fault diagnosis methods are designed to detect any discrepancy between real system and model behaviours, it is assumed that a discrepancy signal is related to (has a response from) a fault. However, the same difference signal can respond to model mismatch or noise in real measurements, which can be (erroneously) detected as a fault, giving rise to a “false alarm” in detection. These considerations have led to research in the field of “robust” methods, in which particular attention

is paid to the discrimination between actual faults and errors due to model mismatch. On the other hand, the availability of a “good” model of the monitored system can significantly improve the performance of diagnostic tools, minimising the probability of false alarms.

This monograph focuses on the explanation of what is a “good” model suitable for robust diagnosis of system performance and operation. The book also describes carefully how “accurate models” can be obtained from real data. A large amount of attention is paid to the “real system modelling problem”, with reference to either linear-non-linear model structures. Special treatment is given to the case in which noise affects the acquired data. The mathematical description of the monitored system is obtained by means of a system identification scheme based on equation error and *errors-in-variables* models. This is a system identification approach that produces a reliable model of the plant under investigation as well as the variances of the input-output noises affecting the data.

After the discussion of identification procedures given in the first two chapters, the monograph focuses on the residual generation problem and fault diagnosis and identification for several cases, namely sensors, actuators and system faults.

The purpose of the monograph is to provide guidelines for the modelling and identification of real processes for fault diagnosis. Hence, significant attention is paid to practical application of the methods described to real system studies, as reported in the last chapters.

Both theoretical and practical arguments have been presented and discussed in a homogenous manner and the book targets both professional engineers working in industry and researchers in academic and scientific institutions.

Dr. S. Simani, Università di Ferrara

Dr. C. Fantuzzi, Università di Modena e Reggio Emilia

Prof. R.J. Patton, Department of Engineering, The University of Hull
Spring, 2002

CONTENTS

Symbols and Abbreviations	xv
1. Introduction	1
1.1 Nomenclature	3
1.2 Fault Detection and Identification Methods based on Analytical Redundancy	5
1.3 Model-based Fault Detection Methods	7
1.4 Model Uncertainty and Fault Detection	8
1.5 The Robustness Problem in Fault Detection	9
1.6 System Identification for Robust FDI	11
1.7 Fault Identification Methods	12
1.8 Report on FDI Applications	13
1.9 Outline of the Book.....	16
1.10 Summary.....	18
2. Model-based Fault Diagnosis Techniques	19
2.1 Introduction	19
2.2 Model-based FDI Techniques	20
2.3 Modelling of Faulty Systems	21
2.4 Residual Generator General Structure.....	28
2.5 Residual Generation Techniques	31
2.5.1 Residual Generation via Parameter Estimation	32
2.5.2 Observer-based Approaches	35
2.5.3 Fault Detection with Parity Equations	40
2.6 Change Detection and Symptom Evaluation	44
2.7 The Residual Generation Problem	45
2.8 Fault Diagnosis Technique Integration.....	51
2.8.1 Fuzzy Logic for Residual Generation	51
2.8.2 Neural Networks in Fault Diagnosis	53
2.8.3 Neuro-fuzzy Approaches to FDI	54
2.8.4 Structure Identification of NF Models	56
2.8.5 NF Residual Generation Scheme for FDI	57
2.9 Summary.....	59

3. System Identification for Fault Diagnosis	61
3.1 Introduction	61
3.2 Models for Linear Systems	62
3.3 Parameter Estimation Methods	64
3.3.1 System Identification in Noiseless Environment	65
3.3.2 System Identification in Noisy Environment	68
3.3.3 The Frisch Scheme in the MIMO Case	73
3.4 Models for Non-linear Dynamic Systems	75
3.4.1 Piecewise Affine Model	75
3.4.2 Model Continuity and Domain Partitioning	79
3.4.3 Local Affine Model Identification	82
3.4.4 Multiple-Model Identification	85
3.5 Fuzzy Modelling and Identification	89
3.5.1 Fuzzy Multiple Inference Identification	90
3.5.2 Takagi-Sugeno Multiple-Model Paradigm	92
3.5.3 Fuzzy Clustering for Fuzzy Identification	95
3.5.4 Product Space Clustering and Fuzzy Model Identification	100
3.5.5 Non-linear Regression Problem and Black-Box Models	103
3.5.6 Fuzzy Model Identification From Clusters	107
3.6 Conclusion	112
4. Residual Generation, Fault Diagnosis and Identification	115
4.1 Introduction	115
4.2 Output Observers for Robust Residual Generation	116
4.3 Unknown Input Observer	119
4.3.1 UIO Mathematical Description	120
4.3.2 UIO Design Procedure	122
4.4 FDI Schemes Based on UIO and Output Observers	122
4.5 Sliding Mode Observers for FDI	127
4.5.1 Sliding Mode Observers	128
4.6 Kalman Filtering and FDI from Noisy Measurements	130
4.7 Residual Robustness to Disturbances	131
4.7.1 Disturbance Distribution Matrix Estimation	132
4.7.2 Additive Non-linear Disturbance and Noise	133
4.7.3 Model Complexity Reduction	133
4.7.4 Parameter Uncertainty	134
4.7.5 Distribution Matrix Low Rank Approximation	135
4.7.6 Model Estimation with Bounded Uncertainty	135
4.7.7 Disturbance Vector and Disturbance Matrix Estimation	136
4.7.8 Distribution Matrix Optimisation	139
4.7.9 Disturbance Distribution Matrix Identification	139
4.8 Residual Generation via Parameter Estimation	141
4.9 Residual Generation via Fuzzy Models	142
4.10 FDI Using Neural Networks	143

4.10.1	Neural Network Basics	145
4.11	Fault Diagnosis of an Industrial Plant at Different Operating Points Using Neural Networks	147
4.11.1	Operating Point Detection and Fault Diagnosis	147
4.11.2	FDI Method Development	149
4.12	Neuro-fuzzy in FDI	150
4.12.1	Methods of Neuro-fuzzy Integration.....	151
4.12.2	Neuro-fuzzy Networks.....	152
4.12.3	Residual Generation Using Neuro-fuzzy Models	154
4.12.4	Neuro-fuzzy-based Residual Evaluation.....	155
4.13	Summary.....	156
5.	Fault Diagnosis Application Studies	157
5.1	Introduction	157
5.2	Physical Background and Modelling Aspects of an Industrial Gas Turbine	158
5.2.1	Gas Turbine Model Description	158
5.3	Identification and FDI of a Single Shaft Industrial Gas Turbine.....	168
5.3.1	System Identification	169
5.3.2	FDI Using Dynamic Observers	176
5.3.3	FDI Using Kalman Filters	183
5.3.4	Fuzzy System Identification and FDI.....	189
5.3.5	Sensor Fault Identification Using Neural Networks	191
5.3.6	Multiple Working Conditions FDI Using Neural Networks	196
5.3.7	FDI Method Development	196
5.3.8	Multiple Operating Point Simulation Results.....	197
5.4	Identification and FDI of Double Shaft Industrial Gas Turbine.....	199
5.4.1	Process Description	199
5.4.2	System Identification	201
5.4.3	FDI Using Unknown Input Observers	203
5.4.4	FDI Using Kalman Filters	208
5.4.5	Disturbance Decoupled Observers for Sensor FDI.....	209
5.4.6	Fuzzy Models for Fault Diagnosis.....	210
5.5	Modelling and FDI of a Turbine Prototype	214
5.5.1	System Modelling and Identification	215
5.6	Turbine FDI Using Output Observers	220
5.6.1	Case 1: Compressor Failure (<i>Component Fault</i>).....	221
5.6.2	Case 2: Fault Diagnosis of the Output Sensor	223
5.6.3	Case 3: Turbine Damage (<i>Turbine Component Fault</i>) ..	227
5.6.4	Case 4: Actuator Fault (<i>Controller Malfunctioning</i>)...	228
5.6.5	FDI in Noisy Environment Using Kalman Filters	233
5.6.6	Fault Isolation	235
5.6.7	Minimal Detectable Faults.....	239
5.7	FDI with Eigenstructure Assignment.....	242

5.7.1	Robust Fault Diagnosis of the Industrial Process	243
5.8	Robust Residual Generation Problem	247
5.9	Summary	249
6.	Concluding Remarks	251
6.1	Suggestions for Future Work	253
6.1.1	Frequency Domain Residual Generation	253
6.1.2	Adaptive Residual Generators	255
6.1.3	Integration of Identification, FDI and Control	256
6.1.4	Fault Identification	256
6.1.5	Fault Diagnosis of Non-Linear Dynamic Systems	258
	References	261
	Index	279

SYMBOLS AND ABBREVIATIONS

The symbols and abbreviations listed here are used unless otherwise stated.

ARMAX	autoregressive moving average exogenous
ARX	autoregressive exogenous
BFDF	Beard fault detection filter
DOS	dedicated observer scheme
EE	equation error
EIV	errors-in-variables
FDD	fault detection and diagnosis
FDI	fault detection and isolation
FFT	fast Fourier transform
GK	Gustafson-Kessel
GOS	generalized observer scheme
IGV	inlet guided vane
KF	Kalman filter
LS	least-squares
MIMO	multiple-input multiple-output
MISO	multiple-input single-output
MLP	multiLayer perceptron
NN	neural network
OO	output observer
OLS	ordinary least-squares
RBF	radial basis function
RLS	recursive least-squares
SISO	single-Input single-Output
TS	Takagi-Sugeno
UIKF	unknown input Kalman filter
UIO	unknown input observer