

# Power Systems

---

Xiao-Ping Zhang, Christian Rehtanz, Bikash Pal

Flexible AC Transmission Systems: Modelling and Control

Xiao-Ping Zhang, Christian Rehtanz,  
Bikash Pal

# Flexible AC Transmission Systems: Modelling and Control

With 156 Figures

 Springer

Dr. Xiao-Ping Zhang  
University Warwick  
School of Engineering  
Coventry CV4 7AL  
United Kingdom  
*x.p.zhang@warwick.ac.uk*

Bikash Pal  
Imperial College London  
Dept. of Electrical & Electronic Engineering  
Exhibition Road  
London SW7 2BT  
United Kingdom  
*b.pal@imperial.ac.uk*

Dr. Christian Rehtanz  
ABB Corporate Research China  
Universal Plaza, 10 Jiuxianqiao Lu  
Chaoyang District  
Beijing, 100016  
P.R. China  
*christian.rehtanz@ieee.org*

Library of Congress Control Number: 2005936513

ISBN-10 3-540-30606-4 Springer Berlin Heidelberg New York  
ISBN-13 978-3-540-30606-1 Springer Berlin Heidelberg New York

This work is subject to copyright. All rights are reserved, whether the whole or part of the material is concerned, specifically the rights of translation, reprinting, reuse of illustrations, recitation, broadcasting, reproduction on microfilm or in other ways, and storage in data banks. Duplication of this publication or parts thereof is permitted only under the provisions of the German Copyright Law of September 9, 1965, in its current version, and permission for use must always be obtained from Springer. Violations are liable to prosecution under German Copyright Law.

**Springer is a part of Springer Science+Business Media**  
springer.com

© Springer-Verlag Berlin Heidelberg 2006  
Printed in Germany

The use of general descriptive names, registered names, trademarks, etc. in this publication does not imply, even in the absence of a specific statement, that such names are exempt from the relevant protective laws and regulations and therefore free for general use.

Typesetting: Digital data supplied by editors  
Final processing by PTP-Berlin Protago-TeX-Production GmbH, Germany  
Cover-Design: deblik, Berlin  
Printed on acid-free paper 89/3141/Yu – 5 4 3 2 1 0

# Foreword

The electric power industry is undergoing the most profound technical, economic and organisational changes since its inception some one hundred years ago. This paradigm change is the result of the liberalisation process, stipulated by politics and followed up by industry. For many years the electric power industry was characterized by a vertically integrated structure, consisting of power generation, transmission/distribution and trading. The liberalisation process has resulted in the unbundling of this organizational structure. Now generation and trading are organised in separate business entities, subject to competition, while the transmission/distribution business remains a natural monopoly. Since the trading of electric energy happens on two levels, the physical level and the contractual level, it has to be recognized that these two levels are completely different. However for understanding the electricity market as a network based industry both levels have to be considered and understood. The fundamental properties of electric energy are as follows:

- Electricity always needs a network for transportation and distribution.
- Electricity cannot be stored in a substantial amount, hence production and consumption have to be matched at each instant of time.
- The physical transport of electricity has nothing to do with the contracts for trading with electricity

The role of the electric network is of prime importance within the electric energy business. Its operation is governed by physical laws. The electric network has a fixed structure consisting of different voltage levels; the higher levels are for transmission purposes whereas the lower levels are used for the distribution tasks. Each network element has a finite capacity, limiting the amount of electricity to be transported or distributed. As a consequence of the liberalisation process the operation of the networks has been pushed closer towards its technical limits. Hence the stress on the system is considerably bigger than in the past. The efficient use of all network elements is of prime interest to the network operator because the cost constraints have also become much tighter than in the past. Recognizing that the operation of a large electric network is a complex and challenging engineering task, it becomes evident that the cost constraints increase the operational complexity considerably. The bigger the interconnected network becomes the more flexibility is required with respect to the cross border trading of electricity. Simultaneously the complexity of operational problems increases due to voltage, angle and frequency stability problems.

The traditional planning approaches for power networks are undergoing a reengineering. The long lasting experience with the power flowing purely from the generation plants to the customers is no longer valid. Growing volatility and increasingly unpredictable system behaviour requires innovative equipment to handle such situations successfully. Keeping in mind that the interconnected power networks have been designed such that each network partner may contribute with reserve power in case of emergency, the trend is now towards extensive cross border energy trading. Another fundamental development is the construction of micro grid on the distribution level. The introduction of dispersed generation close to the customers changes the functionality and the requirements of the distribution networks. The grid operator is requested to provide network access to any interested stakeholder in a transparent and non-discriminatory manner. So, while in the past the power flow in distribution networks was unidirectional, now the system must handle bidirectional power flows. This allows the distribution network to take on more and more the function of a balancing network. At the same time, the capacity of individual elements may not be sufficient to cope with the resulting power flow situations.

Summarizing the current developments, it must be noticed that both planning and operation of electric networks are undergoing fundamental and radical changes in order to cope with the increased complexity of finding economic and reliable network solutions. The operation of the transmission and distribution networks will be closer to their physical limits. The necessity to design electric power networks providing the maximal transmission capacity and at the same time resulting in minimal costs is a great engineering challenge. Innovative operational equipment based on power electronics offers new and powerful solutions. Commonly described by the term 'Flexible AC Transmission Systems' or 'FACTS-devices', such equipment has been available for several years, but has still not been widely accepted by all grid operators for several reasons.

The introduction of innovative equipment has a great impact on the operation. A more flexible transmission or distribution system may cause new problems during normal or disturbed operating states. Furthermore, the proper understanding of innovative equipment is also an educational problem because there is not much experience reported so far with this innovative equipment.

On the other hand, the opportunities for new solutions are substantial and important. FACTS-devices can be utilized to increase the transmission capacity, improve the stability and dynamic behaviour or ensure better power quality in modern power systems. Their main capabilities are reactive power compensation, voltage control and power flow control. Due to their controllable power electronics, FACTS-devices always provide fast control actions in comparison to conventional devices like switched compensation or phase shifting transformers with mechanical on-load tap changers.

This book offers a concise and modern presentation of the timely and important topic of flexible AC transmission networks. There is no doubt that these innovative FACTS-devices will find a definite place in transmission and distribution networks. The complete description of the functionality of such devices is supported with extensive mathematical models, which are required when planning the

use of this type of equipment in electrical networks. The first part of the book deals with the modeling of single and multi-converter FACTS-devices in single and three-phase power flow studies and optimal power flow solutions.

The in depth discussion of the operational and controlling aspects in the second part of the book makes it a most valuable compendium for the design of future electric networks. Without a complete and powerful solution of the control problems, the FACTS-devices will not find their application in power systems because they have to operate in normal and contingency situations in a reliable and economic way. System security must not be weakened by the FACTS-devices, even if the system is operated closer to its limits. The control speed of the FACTS-devices can only be utilized, if they are first given higher priority from the operator, then designed to react in a coordinated but autonomous manner in dynamic or even contingency situations. A novel and original control strategy based on the autonomous control theory fulfilling these requirements is presented in the book.

Due to the influence of FACTS-devices on wide system areas, especially for power flow and damping control, an exchange of system information with the FACTS-controllers is required. A wide area control scheme is introduced and applied for power flow control. The dynamics of FACTS-devices provide effective damping capability. Inter-area oscillations require wide area system supervision and a wide area control scheme. For this application time delays in the wide area control loop play a significant role in the controller design. Based on detailed modeling, an innovative approach is presented considering this time delay, making wide area damping control feasible. Only with such a control scheme, FACTS-devices can be applied beneficially in the future.

Based on the authors' extensive experience, this book is of greatest importance for the practical power engineers for both planning and operational problems. It provides a deep insight into the use of FACTS-devices in modern power systems. Although the technology of modern power electronics will change very quickly, the results presented in this book are sustainable and long lasting. The combination of theoretical and practical knowledge from the international team of authors from academia and industry provides an invaluable contribution for the future application of FACTS-devices. I am convinced that this book will become a standard work in modern power engineering. It will serve equally as a text book for university students as well as an engineering reference for planning and operation of modern power systems.

# Preface

Electricity market activities and a growing demand for electricity have led to heavily stressed power systems. This requires operation of the networks closer to their stability limits. Power system operation is affected by stability related problems, leading to unpredictable system behavior. Cost efficient solutions are preferred over network extensions. In many countries, permits to build new transmission lines are hard to get, which means the existing network has to be enforced to fulfill the changing requirements.

Power electronic network controllers, the so called FACTS-devices, are well known having several years documented use in practice and research. Several kinds of FACTS-devices have been developed. Some of them such as the Thyristor based Static Var Compensator (SVC) are a widely applied technology; others like the Voltage Source Converter (VSC) based Static Compensator (STATCOM) or the VSC-HVDC are being used in a growing number of installations worldwide. The most versatile FACTS-devices, such as Unified Power Flow Controller (UPFC), although still confined primarily to research and development applications, have the potential to be used widely beyond today's pilot installations.

In general, FACTS-devices can be utilized to increase the transmission capacity, the stability margin and dynamic behavior or serve to ensure improved power quality. Their main capabilities are reactive power compensation, voltage control and power flow control. Due to their controllable power electronics, FACTS-device provide always a fast controllability in comparison to conventional devices like switched compensation or phase shifting transformers. Different control options provide a high flexibility and lead to multi-functional devices.

To explore the capabilities of FACTS-devices, a specific operation and control scheme has to be designed. Fundamental to their operation and control is their proper modeling for static and dynamic purposes. The integration of FACTS-devices into basic tools like power flow calculation and optimal power flow (OPF) is mandatory for a beneficial system operation. Due to the wide area and dynamic impact of FACTS-devices, a pure local control is desired, but is not sufficient in many cases. The requirements for normal and emergency operation have to be defined carefully. A specific control design has to address these different operational conditions. This book introduces the latest results of research and practice for modeling and control of existing and newly introduced FACTS-devices.

## ***Motivation***

This book is motivated by the recent developments of FACTS-devices. Numerous types of FACTS-devices have been successfully applied in practical operation. Some are still in the pilot stage and many are proposed in research and development. From practical experience it has been seen that the investment into FACTS-devices, in most of the cases, only pays off by considering their multi-functional capabilities, particularly in normal and emergency situations. This requires a three-phase modeling and a control design addressing both normal and emergency conditions which, in most of the cases, uses wide area information. The recent results and requirements for both modeling and control have motivated this book.

## ***Focus and Target***

The focus and target of this book is to emphasize advanced modeling, analysis and control techniques of FACTS. These topics reflect the recent research and development of FACTS-devices, and foresee the future applications of FACTS in power systems. The book comprehensively covers a range of power system control problems like steady state voltage and power flow control, voltage and reactive power control, voltage stability control and small signal stability control using FACTS-devices.

Beside the more mature FACTS-devices for shunt compensation, like SVC and STATCOM, and series compensation, like TCSC and SSSC, the modeling of the latest FACTS-devices for power flow control, compensation and power quality (IPFC, GUPFC, VSC HVDC and Multi-VSC-HVDC, etc.) is considered for power system analysis. The selection is evaluated by their actual and future practical relevance. The multi-control functional models of FACTS-devices and the ability for handling various internal and external operating constraints of FACTS are introduced. In addition, models are proposed to deal with small or zero impedances in the voltage source converter (VSC) based FACTS-devices. The FACTS-device models are implemented in power flow and optimal power flow (OPF) calculations. The power flow and OPF algorithms cover both single-phase models and especially three-phase models. Furthermore the unbalanced continuation power flow with FACTS is presented.

The control of FACTS-devices has to follow their multi-functional capabilities in normal and emergency situations. The investment into FACTS is normally justified by the increase of stability and primarily by the increase of transmission capability. Applications of FACTS in power system operation and control, such as transfer capability enhancement and congestion management, are used to show the practical benefits of FACTS devices.

A comprehensive FACTS-control approach is introduced based on the requirements and specifications derived from practical experience. The control structure is characterised by an autonomous system structure allowing, as far as possible, control decisions to be taken locally, but also incorporating system wide information where this is required. Wide Area Measurement System (WAMS) based control methodologies, which have been developed recently, are introduced for the

first time in a book. In particular, the real-time control technologies based on Wide Area Measurement are presented. The current applications and future developments of the Wide Area Measurement based control methodologies are also discussed. As a particular control topic, utilizing the control speed of FACTS-devices, a special scheme for small-signal stability and damping of inter-area oscillations is introduced. Advanced control design techniques for power systems with FACTS including eigenvalue analysis, damping control design by the state-of-the art Linear Matrix Inequalities (LMI) approach and multiple damping controller coordination is presented. In addition, the time-delay of wide area communications, which is required for a system wide damping control, is considered.

These aspects make the book unique in its area and differentiate from other books on the similar topic. The work presented is derived both from scientific research and industrial development, in which the authors have been heavily involved. The book is well timed, addressing current challenges and concerns faced by the power engineering professionals both in industries and academia. It covers a broad practical range of power system operation, planning and control problems.

### ***Structure***

The first chapter of the book gives an introduction into nowadays FACTS-devices. Power semiconductors and converter structures are introduced. The basic designs of major FACTS-devices are presented and discussed from a practical point of view. The further chapters are logically separated into a modeling and a control part. The modeling part introduces the modeling of single and multi-converter FACTS-devices for power flow calculations (Chapter 2 and 3) and optimal power flow calculations (Chapter 4). The extension to three phase models is given in chapter 5. This is fundamental for proper system integration for steady state balanced and unbalanced voltage stability control or the increase of available transmission capacity.

Chapter 6 and 7 present the steady state voltage stability analysis for balanced and unbalanced systems. The increase of transmission capacity and loss reduction with power flow controlling FACTS-devices is introduced in chapter 8 along with the financial benefits of FACTS. From these results it can be seen, that the benefits of FACTS can be increased by utilizing the fast controllability of FACTS together with a certain wide area control scheme.

The control part of the book starts with chapter 9 introducing a non-intrusive system control scheme for normal and emergency situations. The chapter takes the view, that a FACTS-device should never weaken the system stability. Based on this condition, the requirements and basic control scheme for FACTS-devices are derived. Chapter 10 introduces an autonomous control system approach for FACTS-control, balancing the use of local and global system information and considering normal and emergency situations. Due to the influence of FACTS-devices on wide system areas, especially for power flow and damping control, an exchange of information with the FACTS controllers is required. A wide area control scheme for power flow control is introduced in chapter 11. Only with wide area system information can the benefits of power flow control be achieved.

The control options available with FACTS-devices can provide effective damping capability. Chapter 12 and 13 deal with small signal stability and the damping of oscillations, which is a specific application area utilizing the control speed of FACTS. The coordination of several FACTS damping controllers requires a formally introduced wide area control scheme. This approach has to consider communication time delays carefully, which is a specific topic of chapter 13.

### **Acknowledgements**

The authors would like to thank Prof. Edmund Handschin at the University of Dortmund, Germany for his support and encouragement to write this book. Significant progress was made in the modeling of FACTS in power flow and optimal power flow analysis when Dr. Zhang was working in Prof. Handschin's Institute at the University of Dortmund, sponsored by the Alexander van Humboldt Foundation, Germany. Subsequent work has been sponsored by the Engineering and Physics Sciences Research Council (EPSRC), UK. Therefore, Dr Zhang would like to take the opportunity to acknowledge the support from the Alexander van Humboldt Foundation and the EPSRC.

Dr. Rehtanz would like to thank the following researchers for their contributions to some of the chapters. Chapter 8 is based on collaborative work with Prof. Jürgen Haubrich, Dr. Feng Li of RWTH, and Dr. Christian Zimmer and Dr. Alexander Ladermann of CONSENTEC GmbH, Aachen, Germany. Dr Christian Becker, who was working with the University of Dortmund, and is now working with AIRBUS Deutschland GmbH, has contributed to chapter 10. Dr. Mats Larsson, Dr. Petr Korba, and Mr. Marek Zima, ABB, Switzerland have contributed with their work to chapter 11. Special thanks are given to Prof. Dirk Westermann of the Technical University Ilmenau, Germany for his useful contributions, inputs and comments to chapters 9 to 11.

Dr. Bikash Pal would like to thank Dr. Balarko Chaudhuri of GE Global Research Lab, Bangalore and Mr Rajat Majumder, a PhD student at Imperial College for supporting him for the preparation of chapter 13 through simulation results. The control design techniques presented in this chapter primarily comes from the research conducted by them under the supervision of Dr. Pal at Imperial College. Dr. Pal also expresses his gratitude to EPSRC (UK) and ABB for sponsoring this research at Imperial College. Dr. Pal is also thankful to Dr. John McDonald of the Control and Power research group at Imperial College for proof reading chapters 12 and 13.

The challenging task of writing and editing this book was made possible by the excellent co-operation of the team of authors together with a number of colleagues and friends. Our sincere thanks to all contributors, proofreaders, the publisher and our families for making this book project happen.

Xiao-Ping Zhang  
Christian Rehtanz  
Bikash Pal

University of Warwick, Coventry, UK, 2005  
ABB China Ltd, Beijing, China, 2005  
Imperial College London, London, UK, 2005

# Contents

- 1 FACTS-Devices and Applications ..... 1**
  - 1.1 Overview..... 2
  - 1.2 Power Electronics ..... 5
    - 1.2.1 Semiconductors ..... 5
    - 1.2.2 Power Converters ..... 8
  - 1.3 Configurations of FACTS-Devices..... 10
    - 1.3.1 Shunt Devices..... 10
    - 1.3.2 Series Devices ..... 15
    - 1.3.3 Shunt and Series Devices ..... 19
    - 1.3.4 Back-to-Back Devices..... 24
  - References..... 25
  
- 2 Modeling of Multi-Functional Single Converter FACTS in Power Flow Analysis ..... 27**
  - 2.1 Power Flow Calculations ..... 27
    - 2.1.1 Power Flow Methods..... 27
    - 2.1.2 Classification of Buses ..... 27
    - 2.1.3 Newton-Raphson Power Flow in Polar Coordinates ..... 28
  - 2.2 Modeling of Multi-Functional STATCOM ..... 28
    - 2.2.1 Multi-Control Functional Model of STATCOM for Power Flow Analysis..... 29
    - 2.2.2 Implementation of Multi-Control Functional Model of STATCOM in Newton Power Flow ..... 35
    - 2.2.3 Multi-Violated Constraints Enforcement ..... 37
    - 2.2.4 Multiple Solutions of STATCOM with Current Magnitude Control . 39
    - 2.2.5 Numerical Examples ..... 40
  - 2.3 Modeling of Multi-Control Functional SSSC..... 44
    - 2.3.1 Multi-Control Functional Model of SSSC for Power Flow Analysis. 44
    - 2.3.2 Implementation of Multi-Control Functional Model of SSSC in Newton Power Flow ..... 48
    - 2.3.3 Numerical Results ..... 51
  - 2.4 Modeling of SVC and TCSC in Power Flow Analysis ..... 54
    - 2.4.1 Representation of SVC by STATCOM in Power Flow Analysis..... 55
    - 2.4.2 Representation of TCSC by SSSC in Power Flow Analysis ..... 56
  - References..... 56
  
- 3 Modeling of Multi-Converter FACTS in Power Flow Analysis ..... 59**

---

3.1 Modeling of Multi-Control Functional UPFC .....	59
3.1.1 Advanced UPFC Models for Power Flow Analysis.....	60
3.1.2 Implementation of Advanced UPFC Model in Newton Power Flow .	66
3.1.3 Numerical Results .....	67
3.2 Modeling of Multi-Control Functional IPFC and GUPFC .....	70
3.2.1 Mathematical Modeling of IPFC in Newton Power Flow under Practical Constraints.....	71
3.2.2 Mathematical Modeling of GUPFC in Newton Power Flow under Practical Constraints.....	75
3.2.3 Numerical Examples .....	78
3.3 Multi-Terminal Voltage Source Converter Based HVDC .....	82
3.3.1 Mathematical Model of M-VSC-HVDC with Converters Co-located in the same Substation.....	83
3.3.2 Generalized M-VSC-HVDC Model with Incorporation of DC Network Equation .....	88
3.3.3 Numerical Examples .....	91
3.4 Handling of Small Impedances of FACTS in Power Flow Analysis .....	95
3.4.1 Numerical Instability of Voltage Source Converter FACTS Models.	95
3.4.2 Impedance Compensation Model .....	95
References .....	97
<b>4 Modeling of FACTS-Devices in Optimal Power Flow Analysis .....</b>	<b>101</b>
4.1 Optimal Power Flow Analysis.....	101
4.1.1 Brief History of Optimal Power Flow .....	101
4.1.2 Comparison of Optimal Power Flow Techniques .....	102
4.1.3 Overview of OPF-Formulation .....	104
4.2 Nonlinear Interior Point Optimal Power Flow Methods.....	105
4.2.1 Power Mismatch Equations.....	105
4.2.2 Transmission Line Limits.....	106
4.2.3 Formulation of the Nonlinear Interior Point OPF .....	106
4.2.4 Implementation of the Nonlinear Interior Point OPF .....	109
4.2.5 Solution Procedure for the Nonlinear Interior Point OPF .....	112
4.3 Modeling of FACTS in OPF Analysis.....	112
4.3.1 IPFC and GUPFC in Optimal Voltage and Power Flow Control .....	113
4.3.2 Operating and Control Constraints of GUPFC.....	113
4.3.3 Incorporation of GUPFC into Nonlinear Interior Point OPF .....	116
4.3.4 Modeling of IPFC in Nonlinear Interior Point OPF .....	121
4.4 Modeling of Multi-Terminal VSC-HVDC in OPF .....	123
4.4.1 Multi-Terminal VSC-HVDC in Optimal Voltage and Power Flow .	123
4.4.2 Operating and Control Constraints of the M-VSC-HVDC.....	123
4.4.3 Modeling of M-VSC-HVDC in the Nonlinear Interior Point OPF ..	124
4.5 Comparison of FACTS-Devices with VSC-HVDC.....	126
4.5.1 Comparison of UPFC with BTB-VSC-HVDC.....	126
4.5.2 Comparison of GUPFC with M-VSC-HVDC .....	128
4.6 Appendix: Derivatives of Nonlinear Interior Point OPF with GUPFC....	131
4.6.1 First Derivatives of Nonlinear Interior Point OPF .....	131

4.6.2 Second Derivatives of Nonlinear Interior Point OPF ..... 133  
 References..... 136

**5 Modeling of FACTS in Three-Phase Power Flow and Three-Phase OPF**

**Analysis ..... 139**  
 5.1 Three-Phase Newton Power Flow Methods in Rectangular Coordinates 140  
     5.1.1 Classification of Buses ..... 140  
     5.1.2 Representation of Synchronous Machines ..... 141  
     5.1.3 Power and Voltage Mismatch Equations in Rectangular Coordinates  
         ..... 142  
     5.1.4 Formulation of Newton Equations in Rectangular Coordinates ..... 143  
 5.2 Three-Phase Newton Power Flow Methods in Polar Coordinates ..... 149  
     5.2.1 Representation of Generators ..... 149  
     5.2.2 Power and Voltage Mismatch Equations in Polar Coordinates ..... 149  
     5.2.3 Formulation of Newton Equations in Polar Coordinates..... 151  
 5.3 SSSC Modeling in Three-Phase Power Flow in Rectangular Coordinates  
     ..... 152  
     5.3.1 Three-Phase SSSC Model with Delta/Wye Connected Transformer  
         ..... 153  
     5.3.2 Single-Phase/Three-Phase SSSC Models with Separate Single Phase  
         Transformers ..... 159  
     5.3.3 Numerical Examples ..... 162  
 5.4 UPFC Modeling in Three-Phase Newton Power Flow in Polar Coordinates  
     ..... 166  
     5.4.1 Operation Principles of the Three-Phase UPFC ..... 166  
     5.4.2 Three-Phase Converter Transformer Models ..... 167  
     5.4.3 Power Flow Constraints of the Three-Phase UPFC ..... 169  
     5.4.4 Symmetrical Components Control Model for Three-Phase UPFC... 172  
     5.4.5 General Three-Phase Control Model for Three-Phase UPFC ..... 175  
     5.4.6 Hybrid Control Model for Three-Phase UPFC..... 176  
     5.4.7 Numerical Examples ..... 178  
 5.5 Three-Phase Newton OPF in Polar Coordinates ..... 183  
 5.6 Appendix A - Definition of  $Yg_i$ ..... 185  
 5.7 Appendix B - 5-Bus Test System..... 185  
 References..... 186

**6 Steady State Power System Voltage Stability Analysis and Control with FACTS..... 189**

6.1 Continuation Power Flow Methods for Steady State Voltage Stability  
 Analysis ..... 189  
     6.1.1 Formulation of Continuation Power Flow ..... 189  
     6.1.2 Modeling of Operating Limits of Synchronous Machines ..... 191  
     6.1.3 Solution Procedure of Continuation Power Flow ..... 192  
     6.1.4 Modeling of FACTS-Control in Continuation Power Flow ..... 193  
     6.1.5 Numerical Results ..... 193  
 6.2 Optimization Methods for Steady State Voltage Stability Analysis ..... 198

6.2.1 Optimization Method for Voltage Stability Limit Determination .... 198  
 6.2.2 Optimization Method for Voltage Security Limit Determination .... 199  
 6.2.3 Optimization Method for Operating Security Limit Determination. 200  
 6.2.4 Optimization Method for Power Flow Unsolvability ..... 200  
 6.2.5 Numerical Examples ..... 202  
 6.3 Security Constrained Optimal Power Flow for Transfer Capability  
 Calculations ..... 204  
 6.3.1 Unified Transfer Capability Computation Method with Security  
 Constraints ..... 205  
 6.3.2 Solution of Unified Security Constrained Transfer Capability Problem  
 by Nonlinear Interior Point Method ..... 206  
 6.3.3 Solution Procedure of the Security Constrained Transfer Capability  
 Problem ..... 211  
 6.3.4 Numerical Results ..... 211  
 References ..... 214

**7 Steady State Voltage Stability of Unbalanced Three-Phase Power Systems ..... 217**

7.1 Steady State Unbalanced Three-Phase Power System Voltage Stability. 217  
 7.2 Continuation Three-Phase Power Flow Approach..... 218  
 7.2.1 Modeling of Synchronous Machines with Operating Limits ..... 218  
 7.2.2 Three-Phase Power Flow in Polar Coordinates..... 219  
 7.2.3 Formulation of Continuation Three-Phase Power Flow ..... 220  
 7.2.4 Solution of the Continuation Three-Phase Power Flow ..... 222  
 7.2.5 Implementation Issues of Continuation Three-Phase Power Flow... 223  
 7.2.6 Numerical Results ..... 224  
 7.3 Steady State Unbalanced Three-Phase Voltage Stability with FACTS ... 232  
 7.3.1 STATCOM..... 232  
 7.3.2 SSSC ..... 234  
 7.3.3 UPFC..... 235  
 References ..... 236

**8 Congestion Management and Loss Optimization with FACTS ..... 239**

8.1 Fast Power Flow Control in Energy Markets..... 239  
 8.1.1 Operation Strategy..... 239  
 8.1.2 Control Scheme ..... 241  
 8.2 Placement of Power Flow Controllers ..... 242  
 8.3 Economic Evaluation Method ..... 245  
 8.3.1 Modelling of LFC for Cross-Border Congestion Management..... 245  
 8.3.2 Determination of Cross-Border Transmission Capacity..... 247  
 8.3.3 Estimation of Economic Welfare Gain through LFC ..... 248  
 8.4 Quantified Benefits of Power Flow Controllers ..... 252  
 8.4.1 Transmission Capacity Increase ..... 252  
 8.4.2 Loss Reduction..... 254  
 References ..... 257

<b>9 Non-Intrusive System Control of FACTS .....</b>	<b>259</b>
9.1 Requirement Specification.....	259
9.1.1 Modularized Network Controllers.....	260
9.1.2 Controller Specification .....	261
9.2 Architecture .....	262
9.2.1 NISC-Approach for Regular Operation.....	264
9.2.2 NISC-Approach for Contingency Operation.....	265
References.....	267
<b>10 Autonomous Systems for Emergency and Stability Control of FACTS ..</b>	<b>269</b>
10.1 Autonomous System Structure .....	269
10.2 Autonomous Security and Emergency Control.....	271
10.2.1 Model and Control Structure .....	271
10.2.2 Generic Rules for Coordination.....	271
10.2.3 Synthesis of the Autonomous Control System .....	274
10.3 Adaptive Small Signal Stability Control.....	281
10.3.1 Autonomous Components for Damping Control.....	281
10.4 Verification .....	282
10.4.1 Failure of a Transmission Line.....	284
10.4.2 Increase of Load .....	286
References.....	288
<b>11 Wide Area Control of FACTS.....</b>	<b>289</b>
11.1 Wide Area Monitoring and Control System .....	289
11.2 Wide Area Monitoring Applications.....	292
11.2.1 Corridor Voltage Stability Monitoring .....	292
11.2.2 Thermal Limit Monitoring .....	296
11.2.3 Oscillatory Stability Monitoring.....	296
11.2.4 Topology Detection and State Calculation.....	301
11.2.5 Loadability Calculation based on OPF Techniques.....	303
11.2.6 Voltage Stability Prediction .....	304
11.3 Wide Area Control Applications.....	307
11.3.1 Predictive Control with Setpoint Optimization .....	307
11.3.2 Remote Feedback Control .....	310
References.....	317
<b>12 Modeling of Power Systems for Small Signal Stability Analysis with FACTS.....</b>	<b>319</b>
12.1 Small Signal Modeling .....	320
12.1.1 Synchronous Generators.....	320
12.1.2 Excitation Systems .....	322
12.1.3 Turbine and Governor Model.....	324
12.1.5 Network and Power Flow Model .....	326
12.1.6 FACTS-Models .....	327
12.1.7 Study System.....	333
12.2 Eigenvalue Analysis .....	334

12.2.1 Small Signal Stability Results of Study System ..... 334  
 12.2.2 Eigenvector, Mode Shape and Participation Factor ..... 340  
 12.3 Modal Controllability, Observability and Residue ..... 343  
 References ..... 346

**13 Linear Control Design and Simulation of Power System Stability with**

**FACTS..... 347**  
 13.1 H-Infinity Mixed-Sensitivity Formulation..... 348  
 13.2 Generalized H-Infinity Problem with Pole Placement..... 349  
 13.3 Matrix Inequality Formulation..... 351  
 13.4 Linearization of Matrix Inequalities ..... 352  
 13.5 Case Study ..... 354  
     13.5.1 Weight Selection ..... 354  
     13.5.2 Control Design ..... 355  
     13.5.3 Performance Evaluation ..... 357  
     13.5.4 Simulation Results..... 358  
 13.6 Case Study on Sequential Design ..... 361  
     13.6.1 Test System ..... 361  
     13.6.2 Control Design ..... 362  
     13.6.3 Performance evaluation ..... 362  
     13.6.4 Simulation Results..... 363  
 13.7 H-Infinity Control for Time Delayed Systems ..... 366  
 13.8 Smith Predictor for Time-Delayed Systems ..... 367  
 13.9 Problem Formulation using Unified Smith Predictor ..... 370  
 13.10 Case Study ..... 372  
     13.10.1 Control Design ..... 373  
     13.10.2 Performance Evaluation ..... 375  
     13.10.3 Simulation Results..... 375  
 References ..... 379

**Index..... 381**